

Strengthening Tsunami and Earthquake Preparedness in Pakistan

Earthquake Hazard Assessment

Tsunami Risk Assessment


Tsunami Bye Laws and Building Codes

Tsunami Early Warning SOPs

Database of Elements at Risk

Tsunami Safe Structures

Vulnerability Assessment of Buildings



Department of Earthquake Engineering
NED University of Engineering & Technology, Karachi

Executive Summary

This report presents the seismic vulnerability assessment of buildings and lifelines structures in Karachi particularly for the coastal belt, based on probabilistic seismic hazard analysis (PSHA) results. The outcome is to present the direct physical damage in built infrastructure include buildings, bridges, electric power network system, harbour system, oil and gas systems, telecommunication system and water and waste water systems. The scope of the work limited to the development of damage matrices considering probabilistic earthquakes to existing structures for an intensity measure peak ground acceleration (PGA) with different damage states (i.e., minor, moderate, extensive or collapse). Fragility curves are developed for each classification based on empirical or analytical approach. The work is mainly divided in to four steps. In the first step, a detailed data collection rubric considering the scope of the project for considered inventories has been developed. In the second step, GIS mapping has been done based on typology classification regarding different existing structures. In the third step, intensity measure peak ground acceleration (PGA) has been extracted from the hazard analysis for different probability of exceedance having a specific return period. In the fourth and final step, the suitable fragility curves are identified from the literature and the corresponding damage matrices for different structures have been plotted. Results show that 25% reinforced concrete buildings, 26% unreinforced concrete buildings, 44% bridges, 10% electric power network system, 5% oil and gas system, 3% telecommunication systems and 9% water and waste water systems are exceeding the collapse limit state at 10% probability of exceedance earthquake.

Contents

Executive Summary	i
List of Tables	iv
List of Figures	vi
Chapter 1 – General Overview	1
Chapter 2 – Classification of Building Structures	2
1.1 Reinforced Concrete Framed Buildings	2
1.1.1 Reinforced Concrete Moment Framed Building (C1)	2
1.1.2 Reinforced Concrete Shear Wall Framed Building (C2)	3
1.1.3 Reinforced Concrete Infilled Framed Building (C3)	3
1.2 Unreinforced Masonry Building (URM)	3
Chapter 3 – Classification of Non-Building Structures	5
3.1 Bridges and Flyovers	5
3.1.1 Wall Piers	5
3.1.2 Multiple Columns/Bent Piers	5
3.1.3 Single Column/Hammerhead Piers	6
3.2 Electric Power Network (EPN) Inventory	7
3.2.1 Electric Power Grid (EPN-01)	7
3.2.2 Generation Plant (EPN-02)	7
3.2.3 Substations (EPN-03)	8
3.3 Harbour System	9
3.3.1 Waterfront Structures	9
3.3.2 Cranes and Cargo Handling Facilities	10
3.3.3 Fuel Facilities	10
3.4 Oil and Gas Systems	10
3.4.1 Refineries	11
3.4.2 Pumping Plants	11
3.4.3 Tank Farms	12
3.5 Communication System	12
3.6 Water and Waste-Water Systems	14
3.6.1 Water treatment plant	14
3.6.2 Pumping Stations	15
3.6.3 Waste-Water treatment plant	15
Chapter 4 – Damage States	17
Chapter 5 – Scope of Work	18

Chapter 6 – Methodology	19
Chapter 7 – Results and Discussion.....	44
Chapter 8 – Conclusions	99
References.....	100

List of Tables

Table 1: Ground plus Five Story Reinforced Concrete Buildings	30
Table 2: Ground plus Six Storeyed Reinforced Concrete Building	30
Table 3: Bent pier supported flyovers	30
Table 4: Single column/Hammerhead pier supported flyovers.....	31
Table 5: Wall pier supported bridges	31
Table 6: List of Low Voltage Transmission line-EPN-01	31
Table 7: List of Medium Voltage Transmission line-EPN-01	31
Table 8: List of Generation Plants-EPN-02	32
Table 9: List of Substations-EPN-03	32
Table 10: Waterfront Structures and Cranes.....	32
Table 11: Cargo Handling Facilities, Steel Tanks and Fuel Facilities	34
Table 12: List of Oil Refineries	34
Table 13: List of Pumping Plants.....	35
Table 14: Tank Farms	37
Table 15: Telephone Exchange Buildings	38
Table 16: List of Transmission Towers	38
Table 17: Water Treatment Plant	38
Table 18: Waste-Water Treatment Plant.....	38
Table 19: List of Pumping Stations (PS)	39
Table 20: Soil Amplification Factors as per UBC-97	40
Table 21: Calculated Mean value of Intensity Measure-PGA for Different Return Periods	40
Table 22: Damage Matrix for Low-rise Concrete Moment Resisting Framed Buildings (C1L)	46
Table 23: Damage Matrix for Mid-rise Concrete Moment Resisting Framed Buildings (C1M).....	46
Table 24: Damage Matrix for High-rise Concrete Moment Resisting Framed Buildings (C1H)	46
Table 25: Damage Matrix for Low-rise Shear Wall Framed Buildings (C2L)	50
Table 26: Damage Matrix for Mid-rise Shear Wall Framed Buildings (C2M)	50
Table 27: Damage Matrix for High-rise Shear Wall Framed Buildings (C2H)	51
Table 28: Damage Matrix for Low-rise Infilled Framed Buildings (C3L)	55
Table 29: Damage Matrix for Mid-rise Infilled Framed Buildings (C3M).....	55
Table 30: Damage Matrix for High-rise Infilled Framed Buildings (C3H)	55
Table 31: Damage Matrix for Unreinforced Stone Masonry Buildings (Cst).....	59
Table 32: Damage Matrix for Unreinforced Block Masonry Buildings (Cbl).....	59
Table 33: Damage Matrix for Single Column Pier	62
Table 34: Damage Matrix for Multiple Columns Pier	62
Table 35: Damage Matrix for Wall Pier	63
Table 36: Damage Matrix for Collapse limit state (EPN-01)	65
Table 37: Damage Matrix for Connectivity Loss (EPN-01)	68
Table 38: Damage Matrix for Anchored Small Generation Plant (EPN-02)	71
Table 39: Damage Matrix for Anchored Medium/Large Generation Plant (EPN-02).....	71
Table 40: Damage Matrix for Anchored Low Voltage Substation (EPN-03).....	74
Table 41: Damage Matrix for Anchored Medium Voltage Substation (EPN-03)	74
Table 42: Damage Matrix for Anchored High Voltage Substation (EPN-03)	75
Table 43: Damage Matrix for Waterfront Structures.....	77
Table 44: Damage Matrix for Stationery Equipment.....	79
Table 45: Damage Matrix for Rail Mounted Equipment	79

Table 46: Damage Matrix for Fuel Facilities (High Seismic Building with Unanchored Components)	81
Table 47: Damage Matrix for Small Oil Refineries with Anchored Components	83
Table 48: Damage Matrix for Medium/Large Oil Refineries with Anchored Components	84
Table 49: Damage Matrix for High Seismic Pumping Plants with Anchored Components	86
Table 50: Damage Matrix for Anchored Tank Farms	87
Table 51: Damage Matrix for Communication Facilities with anchored components	89
Table 52: Damage Matrix for Anchored Water Treatment Plant	91
Table 53: Damage Matrix for Low Seismic RC Building Waste Water Treatment Plant	93
Table 54: Damage Matrix for High Seismic RC Building Waste Water Treatment Plant	94
Table 55: Damage Matrix for Low Seismic RC Building Pumping Stations	96
Table 56: Damage Matrix for High Seismic RC Building Pumping Stations	97

List of Figures

Figure 1: Reinforced Concrete Moment Framed Building (C1)	2
Figure 2: Reinforced Concrete Shear Wall Framed Building (C2).....	3
Figure 3: Reinforced Concrete Infilled Framed Building (C3).....	3
Figure 4: Unreinforced Masonry Building (URM).....	4
Figure 5: Solid Wall Piers (a) monolithic with superstructure, (b) non-monolithic with superstructure	5
Figure 6: Bent Pier (a) for precast girders, and (b) for cast-in-place girders	6
Figure 7: Single Column hammerhead Pier (a) monolithic with superstructure, (b) non-monolithic with superstructure.....	6
Figure 8: Electric Power Grid (EPN-01).....	7
Figure 9: Generation Plant (EPN-02).....	8
Figure 10: Substation (EPN-03).....	9
Figure 11: Waterfront Structures (Wharves, Seawalls and Piers).....	9
Figure 12: Cranes and Cargo Handling Facilities	10
Figure 13: Fuel Facilities	10
Figure 14: view of a Refinery	11
Figure 15: Pumping Plants.....	12
Figure 16: Tank Farms.....	12
Figure 17: 2004, Indian Ocean Tsunami.....	13
Figure 18: Fault Tree diagram Of Telephone Central Office Building Failure	14
Figure 19: Water Treatment Plant.....	15
Figure 20: Pumping Station (PS)	15
Figure 21: Waste-Water Treatment Plant	16
Figure 22: Damage States proposed by HAZUS	17
Figure 23: Building Stock data rubric.....	19
Figure 24: Bridges and Flyovers data rubric.....	20
Figure 25: Electric power network data rubric	20
Figure 26: Harbor System data rubric	21
Figure 27: Oil and Gas System data rubric	22
Figure 28: Telecommunication network data rubric.....	23
Figure 29: Water and Waste-Water Systems data rubric	24
Figure 30: Reinforced Concrete Building Stock in Case-study Area	25
Figure 31: Identified flyovers in the case-study area.....	25
Figure 32: Identified bridges in the case-study area	26
Figure 33: Power Grid-EPN-01	26
Figure 34: Generation Plant-EPN-02.....	27
Figure 35: Substations-EPN-03	27
Figure 36: Waterfront Structures, Cranes and Fuel Facilities.....	28
Figure 37: Refineries, Pumping Plants and Tank Farms.....	28
Figure 38: Telephone Exchange Buildings and Transmission Towers.....	29
Figure 39: Water treatment plant, Waste-water treatment plant and Pumping stations.....	29
Figure 40: Spatial Distribution for annual probability of exceedance of the ground motion in terms of PGA-intensity measure in 50 years (a) 70 percent probability of exceedance (53 YRP) (b) 50 percent probability of exceedance (80 YRP) (c) 25 percent probability of exceedance (178 YRP) (d) 10 percent probability of exceedance (476 YRP) (e) 5 percent probability of exceedance (976 YRP) (f) 2 percent probability of exceedance (2475 YRP).....	39
Figure 41: Vs30 values in Case-study area (Kumar et al., 2015)	40

Figure 42: Fault-tree analysis proposed by HAZUS (NIBS 2004) for tank farms	41
Figure 43: Seismic Risk Mitigation approach for lifelines and infrastructures	42
Figure 44: Earthquake Loss estimation Methodology (FEMA-HAZUS Technical manual-2003)	43
Figure 45: Fragility Curves for Low-rise Reinforced Concrete Moment Frame (C1L)	44
Figure 46: Fragility Curves for Mid-rise Reinforced Concrete Moment Frame (C1M)	45
Figure 47: Fragility Curves for High-rise Reinforced Concrete Moment Frame (C1H)	45
Figure 48: Low-rise Concrete Moment Resisting Framed Buildings (C1L)	47
Figure 49: Mid-rise Concrete Moment Resisting Framed Buildings (C1M)	47
Figure 50: High-rise Concrete Moment Resisting Framed Buildings (C1H)	48
Figure 51: Fragility Functions for Low-rise Shear Wall Framed Building (C2L)	49
Figure 52: Fragility Functions for Mid-rise Shear Wall Framed Building (C2M)	49
Figure 53: Fragility Functions for High-rise Shear Wall Framed Building (C2H)	50
Figure 54: Damage Matrix for Low-rise Shear Wall Framed Building (C2L)	51
Figure 55: Damage Matrix for Mid-rise Shear Wall Framed Building (C2M)	52
Figure 56: Damage Matrix for High-rise Shear Wall Framed Building (C2H)	52
Figure 57: Fragility Functions for Low-rise Infilled Framed Building (C3L)	53
Figure 58: Fragility Functions for Mid-rise Infilled Framed Building (C3M)	54
Figure 59: Fragility Functions for High-rise Infilled Framed Building (C3H)	54
Figure 60: Damage Matrix for Low-rise Infilled Framed Building (C3L)	56
Figure 61: Damage Matrix for Mid-rise Infilled Framed Building (C3M)	56
Figure 62: Damage Matrix for High-rise Infilled Framed Building (C3H)	57
Figure 63: Fragility Functions for Unreinforced Stone Masonry Building (Cst)	58
Figure 64: Fragility Functions for Unreinforced Block Masonry Building (Cbl)	58
Figure 65: Damage Matrix for Unreinforced Stone Masonry Buildings	59
Figure 66: Damage Matrix for Unreinforced Block Masonry Buildings	60
Figure 67: Fragility Functions for Single Column Pier	61
Figure 68: Fragility Functions for Multiple Columns Pier	61
Figure 69: Fragility Functions for Wall Pier	62
Figure 70: Damage Matrix for Single Column Pier	63
Figure 71: Damage Matrix for Multiple Columns Pier	64
Figure 72: Damage Matrix for Wall Pier	64
Figure 73: Collapse limit state for EPN-01	65
Figure 74: Damage Matrix for Collapse limit state for EPN-01 with Low Voltage Transmission lines	66
Figure 75: Damage Matrix for Collapse limit state for EPN-01 with Medium Voltage Transmission lines	66
Figure 76: Damage Matrix for Collapse limit state for EPN-01 with High Voltage Transmission lines	67
Figure 77: Fragility Functions in terms of Connectivity Loss (EPN-01)	67
Figure 78: Damage Matrix in terms of 20% Connectivity Loss (EPN-01)	68
Figure 79: Damage Matrix in terms of 50% Connectivity Loss (EPN-01)	69
Figure 80: Damage Matrix in terms of 80% Connectivity Loss (EPN-01)	69
Figure 81: Fragility Functions for Anchored-Small Generation Plant (EPN-02)	70
Figure 82: Fragility Functions for Anchored-Medium/Large Generation Plant (EPN-02)	70
Figure 83: Fragility Functions for Anchored Small Generation Plant (EPN-02)	71
Figure 84: Fragility Functions for Anchored-Medium/Large Generation Plant (EPN-02)	72
Figure 85: Fragility Functions for Anchored-Low Voltage Substation (EPN-03)	73
Figure 86: Fragility Functions for Anchored-Medium Voltage Substation (EPN-03)	73

Figure 87: Fragility Functions for Anchored-High Voltage Substation (EPN-03)	74
Figure 88: Damage Matrix for Anchored-Low Voltage Substation (EPN-03)	75
Figure 89: Damage Matrix for Anchored-Medium Voltage Substation (EPN-03)	76
Figure 90: Damage Matrix for Anchored-High Voltage Substation (EPN-03)	76
Figure 91: Fragility Functions for Waterfront Structures	77
Figure 92: Damage Matrix for Waterfront Structures	78
Figure 93: Fragility function for Stationery Equipment	79
Figure 94: Fragility function for Rail Mounted Equipment	79
Figure 95: Damage Matrix for Stationary Equipment	80
Figure 96: Damage Matrix for Rail Mounted Equipment	80
Figure 97: Fragility Functions for Fuel Facilities (High Seismic Building with Unanchored Components)	81
Figure 98: Damage Matrix for Fuel Facilities (High Seismic Building with Unanchored Components)	82
Figure 99: Fragility Functions for Small Oil Refineries with Anchored Components	83
Figure 100: Fragility Functions for Medium/Large Oil Refineries with Anchored Components	83
Figure 101: Fragility Functions for Small Oil Refineries with Anchored Components	84
Figure 102: Fragility Functions for Medium/Large Oil Refineries with Anchored Components	85
Figure 103: Fragility function for High Seismic Pumping Plants with Anchored Components	85
Figure 104: Damage Matrix for High Seismic Pumping Plants with Anchored Components	86
Figure 105: Fragility Functions for Anchored Tank Farms	87
Figure 106: Damage Matrix for Anchored Tank Farms	88
Figure 107: Fragility Functions for Communication Facilities with anchored components	89
Figure 108: Damage Matrix for Communication Facilities with anchored components	90
Figure 109: Fragility Functions for Anchored Water Treatment Plant	91
Figure 110: Damage Matrix for Anchored Water Treatment Plant	92
Figure 111: Fragility function for Low Seismic RC Building Waste Water Treatment Plant	93
Figure 112: Fragility function for High Seismic RC Building Waste Water Treatment Plant	93
Figure 113: Damage Matrix for Low Seismic RC Building Waste Water Treatment Plant	94
Figure 114: Fragility function for High Seismic RC Building Waste Water Treatment Plant	95
Figure 115: Fragility Functions for Low Seismic RC Building Pumping Stations	96
Figure 116: Fragility Functions for High Seismic RC Building Pumping Stations	96
Figure 117: Damage Matrix for Low Seismic RC Building Pumping Stations	97
Figure 118: Damage Matrix for High Seismic RC Building Pumping Stations	98

Chapter 1 – General Overview

As urban development continues in seismically hazardous regions of the Pakistan, there is growing concern about the exposure of buildings, lifelines (e.g., utilities and transportation systems), and population to the potential effects of earthquakes. Earthquake risk analysis begins with hazard evaluation, and goes beyond that to determine the potential earthquake consequences on people and property, including buildings, lifelines and environment.

The prime focus of this report is to estimate the direct physical damage to the built infrastructure in Karachi including buildings, bridges, electric power network system, harbor system, oil and gas system, telecommunication system and water and waste water systems.

The key assumption in the vulnerability assessment of buildings and lifeline components is that structures having similar structural characteristics (and being in similar geotechnical conditions) are expected to perform in the same manner for a given seismic loading (SYNER-G, 2013).

In seismic risk assessment or seismic vulnerability analysis, the fragility curve is a valuable tool to estimate the degree of damage to infrastructure during an earthquake. Fragility curves express the conditional probability of reaching or exceeding a particular damage state (DS_i) given a certain level of seismic intensity measure (IM). A lognormal cumulative distribution function (CDF) typically used to develop the fragility function with respect to the intensity measure (IM) such as peak ground acceleration-PGA (NIBS, 2004; Argyroudis and Pitilakis, 2012; Qiu et al., 2018).

Fragility curves can be classified into the four generic groups; empirical, judgmental, analytical, and hybrid, according to whether the damage data used in their generation stems mainly from observed post-earthquake surveys, expert opinion, analytical simulations, or combinations of these, respectively (Rossetto & Elnashai, 2003). The empirical fragility curves are derived for a damage state through the statistical damage data reported in post-earthquake surveys from previous seismic events (Rota et al. 2008; Spence et al., 2008). The limitations of empirical approach are the unavailability of sufficient and reliable statistical data for a wide range of intensities. The judgement based fragility functions rely on the opinions of expert panels of engineers with experience in earthquake engineering who are asked to make estimates of the likely damage distribution within building populations when subjected to earthquakes of variant intensities. The analytical fragility curves are derived through the numerical simulations of structures process through real/artificial ground motions or by pushover analysis. Finally, the hybrid fragility curves attempt to compensate for the scarcity of observational data, subjectivity of judgmental data and modelling deficiencies of analytical procedures, by combining data from different sources. In this report, the analytical and empirical both approaches are utilized to estimate the degree of damage in buildings, bridges and others utilities.

Chapter 2 – Classification of Building Structures

Classification of structures is the key step for vulnerability assessment studies. This report broadly categorized structures into building and non-building structures. The building structures categorized into reinforced concrete (RC) buildings and unreinforced masonry (URM) buildings.

1.1 Reinforced Concrete Framed Buildings

The general building stock in Karachi includes residential, commercial, industrial, religious, government and educational buildings. Majority of the buildings are not designed and constructed as per modern seismic code provisions. These buildings can be categorized as pre-code building structures which comprise of concrete frame with unreinforced masonry infill walls (low-rise to mid-rise) and unreinforced masonry bearing wall buildings (low-rise). Only, limited building stock in Karachi after the 2005 earthquake has been designed and constructed as per Building Code of Pakistan (BCP)-2007. These well design structures include concrete moment resisting frame and concrete shear wall frame typically used for mid-rise to high-rise construction and designed for moderate level of seismicity.

1.1.1 Reinforced Concrete Moment Framed Building (C1)

These buildings have a frame of concrete columns and beams, in which lateral and gravity loads are resisted by beams and columns (Figure 1). Usually the structure is concealed on the outside by exterior non-structural walls, which can be of almost any material (curtain walls, or concrete blocks). Diaphragms (slabs) transfer the lateral loads to moment-resisting frames. The frames develop their stiffness by full or partial moment connections. Some older concrete frames may be proportioned and detailed such that brittle failure of the frame members can occur in earthquakes leading to partial or full collapse of the buildings. Modern frames in zones of high seismicity are proportioned and detailed for ductile behavior and are likely to undergo large deformations during an earthquake without brittle failure of frame members and collapse.




Figure 1: Reinforced Concrete Moment Framed Building (C1)

1.1.2 Reinforced Concrete Shear Wall Framed Building (C2)

These building structures have higher stiffness as compared to reinforced concrete moment resisting frame buildings and are typically used in high-rise construction (Figure 2). The vertical components of the lateral-force-resisting system in these buildings are reinforced concrete columns and shear walls, significant part of lateral loads is resisted by concrete shear walls.



Figure 2: Reinforced Concrete Shear Wall Framed Building (C2)

1.1.3 Reinforced Concrete Infilled Framed Building (C3)

Reinforced concrete infilled framed building-C3 is the older and widely used building typology in Karachi (Figure 3). These buildings are less ductile as compared to moment resisting framed buildings due to the presence of unreinforced masonry infill walls. In these buildings, the shear strength of the columns (after cracking of the infill) may limit the semi-ductile behaviour of the system.



Figure 3: Reinforced Concrete Infilled Framed Building (C3)

1.2 Unreinforced Masonry Building (URM)

In these buildings, lateral and gravity loads are resisted by bearing walls. Bearing walls are generally made of concrete blocks and stone masonry. These buildings include structural elements that vary depending on the building's age. In buildings built before 1900, the majority

of floor and roof construction consists of wood sheathing supported by wood framing (Figure-04).




Figure 4: Unreinforced Masonry Building (URM)

Chapter 3 – Classification of Non-Building Structures

The non-building stocks include bridges and flyovers, electric power network system (EPN), harbor system, oil and gas system, communication system, and water and waste water systems.

3.1 Bridges and Flyovers

Similar to other essential structures such as hospitals, police stations and fire stations, bridges and flyovers are also important components of a road network which are termed as lifeline structures. It is vital that these structures remain functional in case of a natural calamity to facilitate relief operations. In current study, bridges and flyovers have been classified in this report on the basis of supporting sub-structure and mainly on the typology of pier below the superstructure. On the basis of pier, there are three types of bridges and flyovers, (a) supported on single column, (b) supported on multiple columns or bent, and (c) supported on wall pier. In order to estimate the different levels of damage fragility functions obtained through analytical study (Khan et al., 2015) have been employed in this report. Nonlinear static pushover analysis is primarily used in analytical approach to estimate the damage at component level and particularly in piers.

3.1.1 Wall Piers

Solid wall piers (Figure 5) are often used at water crossings since they can be constructed to proportions that are both slender and streamlined. These features lend themselves well for providing minimal resistance to flood flows.




Figure 5: Solid Wall Piers (a) monolithic with superstructure, (b) non-monolithic with superstructure

3.1.2 Multiple Columns/Bent Piers

A column bent pier consists of a cap beam and supporting columns forming a frame. Column bent piers (Figure 6) can either be used to support a steel girder superstructure or be used as an integral pier where the cast-in-place construction technique is used. The columns can be either circular or rectangular in cross section. These are by far the most popular forms of piers in the modern highway system.




Figure 6: Bent Pier (a) for precast girders, and (b) for cast-in-place girders

3.1.3 Single Column/Hammerhead Piers

Hammerhead piers (Figure 7) are often found in urban areas where space limitation is a concern. These are used to support steel girder or precast pre-stressed concrete superstructures, aesthetically appealing, generally occupy less space and provide more room for the traffic underneath.




Figure 7: Single Column hammerhead Pier (a) monolithic with superstructure, (b) non-monolithic with superstructure

3.2 Electric Power Network (EPN) Inventory

A modern EPN system is a complex interconnected system, which includes electric power grids, generation facilities, substations, etc. All of these components are vulnerable to damage during the earthquakes, which may result in significant disruption of power supply. Three components of EPN System have been considered such as electric power grid (EPN-01), generation plant (EPN-02) and substation (EPN-03).

3.2.1 Electric Power Grid (EPN-01)

Electric power grid (also known as the distribution system) is divided into a number of circuits. A distribution circuit includes poles, wires, in-line equipment and utility-owned equipment at customer sites. A distribution circuit also includes above ground and underground conductors. Distribution circuits either consist of anchored or unanchored components. EPN-01 is further categorized into high voltage (capacity greater than 350KV), moderate voltage (capacity ranges from 350KV to 150KV) and low voltage (capacity less than 150KV) transmission lines (Figure 8).



Figure 8: Electric Power Grid (EPN-01)

3.2.2 Generation Plant (EPN-02)

Generation plants (

Figure 9) produce alternating current (AC) and these plants subcomponents include diesel generators, turbines, racks and panels, boilers and pressure vessels, and the building in which these are housed. The size of the generation plant is determined from the number of Megawatts of electric power that the plant can produce under normal operations. Generation plants have been classified as small generation plants having a generation capacity less than 200

Megawatts. Medium/large generation plants having a capacity greater than 200 Megawatts. The classification is also a function of whether the subcomponents are anchored or unanchored.



Figure 9: Generation Plant (EPN-02)

3.2.3 Substations (EPN-03)

An electric substation (Figure 10) is a facility that serves as a source of energy supply for the local distribution area in which it is located, and has several main functions such as,

- Change or switch voltage from one level to another
- Provide points where safety devices such as disconnect switches, circuit breakers, and other equipment can be installed
- Regulate voltage to compensate for system voltage changes
- Eliminate lightening and switching surges from the system
- Convert AC to direct current (DC) and DC to AC, as needed
- Change frequency, as needed

Substations can be entirely enclosed in buildings where all the equipment are assembled into one metal clad unit. In the employed loss estimation methodology, only transmission (138 kV to 765 kV or higher) and sub-transmission (34.5 kV to 161 kV) substations are considered. These will be classified as high voltage (350 kV and above), medium voltage (150 kV to 350 kV) and low voltage (34.5 kV to 150 kV). The classification is also a function of whether the subcomponents are anchored or unanchored.



Figure 10: Substation (EPN-03)

3.3 Harbour System

Harbour system consists of four components: waterfront structures (e.g., wharfs, piers and seawalls); cranes and cargo handling equipment; fuel facilities; and warehouses. In many cases, these facilities were constructed prior to widespread use of engineered fills; consequently, the wharf, pier, and seawall structures are prone to damage due to soil failures such as liquefaction. Other components may be damaged due to ground shaking as well as ground failure.

3.3.1 Waterfront Structures

Waterfront structures include wharves (harbour embankments), seawalls (protective walls from erosion), and piers (break-water structures which form harbours) that exist in the port system (Figure 11). Waterfront structures typically are supported by wood, steel or concrete piles. Many also have batter piles to resist lateral loads from wave action and impact of vessels. Seawalls are caisson walls retaining earth fill material.



Figure 11: Waterfront Structures (Wharves, Seawalls and Piers)

3.3.2 Cranes and Cargo Handling Facilities

These are large equipment items used to load and unload freight from vessels (Figure 12). These are stationary or mounted on rails.



Figure 12: Cranes and Cargo Handling Facilities

3.3.3 Fuel Facilities

The fuel facility consists mainly of fuel storage tanks, buildings, pump equipment, piping, and, sometimes, backup power (Figure 13). The functionality of fuel systems is determined with a fault tree analysis.



Figure 13: Fuel Facilities

3.4 Oil and Gas Systems

Oil and gas systems are on high risk and susceptible to damage from moderate to severe earthquakes. Past earthquakes show that seismic damage to oil and gas elements can cause

extended direct and indirect socio-economic losses with significant environmental impact. This system consists of refineries, pipelines, pumping stations and tank farms. All of these components are vulnerable to damage during earthquakes, which may result in a significant disruption to the oil and gas network. Three components of oil and gas system have been considered in this report refineries, pumping plants and tank farms.

3.4.1 Refineries

A refinery (Figure 14) is an industrial process plant where crude oil is processed and refined into useful petroleum products. Oil refineries serve an important role in the production of transportation and other fuels. Refineries are categorized into small and medium/large refineries based on capacity in barrels per day with anchored and unanchored components.



Figure 14: view of a Refinery

3.4.2 Pumping Plants

Pumping plants (Figure 15) serve to maintain the flow of oil in cross-country pipelines. Pumping plants usually use two or more pumps. Pumps can be of either centrifugal or reciprocating type. However, no differentiation is made between these two types of pumps in

the analysis of oil systems. Pumping plants are classified as having either anchored or unanchored subcomponents.



Figure 15: Pumping Plants

3.4.3 Tank Farms

Tank farms are facilities that store fuel products (Figure 16). They include tanks, pipes and electric components. Tank farms are classified as having either anchored or unanchored subcomponents.



Figure 16: Tank Farms

3.5 Communication System

A communication facility consists of a building (generic type is assumed in the methodology of work in this report), central switching equipment (i.e., digital switches, anchored or unanchored), and back-up power supply (i.e. diesel generators or battery generators, anchored or unanchored) that may be needed to supply the requisite power to the center in case of loss of off-site power. Telecommunication infrastructures are designed to provide connections over long distance for communication. The seismic vulnerability assessment of communication systems comprises of two main ingredients, the functionality assessment of network components and the interconnection among them.

Common failures found in telecommunication network components are failures of electronic equipment, such as computers, server cabinets, switch boards, circuit boards, and battery racks. Without proper anchorage, they are likely to rock or overturn during an earthquake. On 26th December 2004, an earthquake of 9.0 -9.3 magnitude hit the Sumatra and Andaman Islands. Depending on the region, there were tremendous number of injuries, casualties, property damage and destruction to lifeline. Tsunami (Figure 17) crippled telecommunication system by damaging poles, towers and local switching equipment.



Figure 17: 2004, Indian Ocean Tsunami

Functionalities of infrastructural networks are dependent upon functionalities of their components. The concept of system reliability and fault tree analysis are frequently used to assess probabilistic functionality of infrastructure facilities and systems (FEMA 2004, Leelardcharoen 2005, Adachi 2007). A fault tree diagram is a representation of a failure event which consists of combined effects of several sub-events (Melchers 1999). A fault tree diagram typically consists of event blocks and operation gates. Figure 18 presents the fault tree diagram of the failure of a telephone central office as described in (FEMA 2004). The failure results from moderate damage to the central office structure, a dislodged digital switching board, or loss of electric power, where the loss of electric power results from the loss of backup power and commercial power at the same time.




Figure 18: Fault Tree diagram Of Telephone Central Office Building Failure

Central offices and broadcasting stations (including transmission towers) are the only components of the communication system considered in this report as per HAZUS (NIBS-2004) methodology. Therefore, fragility curves are presented for these components only. Other components, such as cables and other lines, usually have enough slack to accommodate ground shaking.

3.6 Water and Waste-Water Systems

Water and waste-water systems are on high risk and are susceptible to damage from moderate to severe earthquakes. Past earthquakes show that seismic damage to water system elements can cause extended direct and indirect socio-economic losses with significant environmental impact. This system consists of supply, storage, transmission, and distribution components. All of these components are vulnerable to damage during earthquakes, which may result in a significant disruption to the water utility network. Three components of Water and Waste-Water Systems have been considered in this report, which include water treatment plant, pumping stations and waste-water treatment plant.

3.6.1 Water treatment plant

Water treatment plants are complex facilities (Figure 19) that are generally composed of a number of connected physical and chemical unit processes whose role is to improve the water quality. Common components include pre-sedimentation basins, aerators, detention tanks, flocculators, clarifiers, backwash tanks, conduit and channels, coal sand or sand filters, mixing tanks, settling tanks, clear wells, and chemical tanks. Main typology parameters include size, anchorage of sub-components, equipment and backup power.



Figure 19: Water Treatment Plant

3.6.2 Pumping Stations

A pumping station (Figure 20) is a facility that boosts water pressure in both transmission and distribution systems. They typically comprise buildings, importation structures, pumps and motor units, pipes, valves and associated electrical and control equipment. Main classification parameters include size, anchorage of sub-components, equipment and backup power.



Figure 20: Pumping Station (PS)

3.6.3 Waste-Water treatment plant

Waste-water treatment plants (Figure 21) are complex facilities which include a number of buildings and underground or on-ground reinforced concrete tanks and basins. Common components include trickling filters, clarifiers, chlorine tanks, recirculation and waste-water pumping stations, chlorine storage and handling, tanks and pipelines. Concrete channels are

used to convey the waste-water from one location to another within the network. The mechanical, electrical and control equipment (as well as piping and valves) are housed within buildings. Main typology parameters include size, anchorage of sub-components, equipment and backup power, building categorization based on low seismic and advance seismic design.



Figure 21: Waste-Water Treatment Plant

Chapter 4 – Damage States

In seismic risk assessment, the performance levels of a structure can be defined through damage thresholds called limit states. A limit state defines the boundary between different damage conditions, whereas the damage state defines the damage condition itself. Different damage criteria have been proposed depending on the typology of element at risk and the approach used for the derivation of fragility curves. The degree of damage for building and non-building structures has been estimated by incorporating variant levels of damage proposed by HAZUS in this report (Figure 22). These damage states are slight, moderate, extensive, and complete damage.




Figure 22: Damage States proposed by HAZUS

Chapter 5 – Scope of Work

The scope of the work for this report includes development of damage matrices considering probabilistic earthquakes to existing structures in Karachi using knowledge of typologies, classification, and the ground motion intensity measure (i.e., peak ground acceleration-PGA). In this report, damage states (i.e., minor, moderate, extensive or collapse) describing the level of damage to each of the existing structure classification have been employed. Fragility curves are developed for each classification based on empirical or analytical approaches. These curves describe the probability of reaching or exceeding each damage state of a particular level of ground motion. Based on fragility curves, the method for assessing the functionality of each category of structure is presented. Buildings, bridges, electric power network system, harbour system, oil and gas system, telecommunication system and water and waste water systems are included in this report.

The selected building typologies are reinforced and non-reinforced buildings which is further classified into reinforced concrete moment framed (C1), reinforced concrete shear wall framed (C2), reinforced concrete infilled framed (C3), and unreinforced masonry structures (URM). Bridges and flyovers, further classified based upon the types of supporting pier typologies such as single column pier, multiple column pier and wall pier. For an electric power system, the selected components are power grids, generation plants and substations. The power grids are also known as transmission lines and are further divided into low voltage, medium voltage and high voltage transmission lines. The generation plants are further classified into small, medium and large generation plants, whereas the substations typologies are similar to power grids. In harbour system, the components include waterfront structures, cranes and cargo handling facilities, steel tanks and fuel facilities which are further divided into anchored and unanchored components. In an oil and gas system, the considered components are refineries, pumping plants, and tank farms. These components are further classified based on capacities and with anchored or unanchored components. In communication facilities considered the components include building type, switching equipment, backup power and off-site power, further classification based on anchored and unanchored components. In the water and waste water systems, the selected components are treatment plants and pumping stations, which are further classified on the basis of sizes and design considerations.

Chapter 6 – Methodology

The work is divided into four steps. In the first step, a detailed data collection rubric considering the scope of the project for considered inventory has been developed as shown in Figures 23-29.

Bldg ID								
Building Address	Name		Block	House No.	Street No.	District	Colony	
Coordinates	Latitude				Longitude			
Plan Dimension	Length				Width			
Occupancy	I .Agricultural, Temporary, Minor Storage Facility or with no occupants at most times.				II .Residential, Commercial, Small Industry, facilities (occupants < 250) or small clinics (occupants < 50)			
	III .Utility Generation / Transmission, Toxic / Explosive holding, Educational, Large Public & Private, Large Clinics or High Occupancy facilities				IV .Hospitals, Rescue & Emergency, Disaster Shelter, Airport or National Defense facilities			
	Building Use							
Non - RCC Building Materials	Walls & Column	Brick Masonry	Adobe Masonry	Block Masonry	Wood / bamboo	Reinforced Masonry	Stone Masonry	Other
	Roof	Cement sheet	Metal Sheet	Cement Tile-beam	Wood / bamboo	Other		
RCC Buildings Information	No. of Stories		Storey Height		B. Wall Height		Gate Height	
	Boundary Wall type				Entrance Gate			
	Front	2 Sided	Grilled	None	Solid		Grilled	
Physical Condition	Building Initial Condition - Damage Grade							
	Grade - 0	None	No Structural and Non Structural Damage					
	Grade - 1	Slight	Hairline cracks in walls, plaster broken, seepage (all non structural).					
	Grade - 2	Moderate	Cracks in beams / columns, reinforcement exposed, concrete deterioration (all structural in addition to non-structural)					
Comments								

Figure 23: Building Stock data rubric

Structure ID					
Structure Address	Name	Block	District	Colony	
Coordinates	Latitude		Longitude		
Plan dimension					
Typology	Wall Pier	Bent Pier	Single Column Pier		
Fixity	Anchored	Anchored	Anchored		
	Unanchored	Unanchored	Unanchored		
Physical Codition	Structure Condition-Damage Grade				
	Grade-0	None			
	Grade-1	Slight			
	Grade-2	Moderate			
Comments					

Figure 24: Bridges and Flyovers data rubric

Structure ID				
Structure Address	Name	Block	District	Colony
Coordinates	Latitude		Longitude	
Plan dimension				
	Typology		Analysis level	Element code
	Electric power grid		Network	EPN01
	Generation plant		Station	EPN02
	Substation		Station	EPN03
Typology	EPN-01	EPN-02	EPN-03	
	HV > 350KV	Small <200MW	Low <150KV	
	MV (350 KV to 150KV)	Medium/large	Medium (150KV to 350KV)	
	LV < 150KV	>200MV	High >350KV	
Fixity				
		Anchored	Anchored	
		Unanchored	Unanchored	
Physical Codition	Structure Condition-Damage Grade			
	Grade-0	None		
	Grade-1	Slight		
	Grade-2	Moderate		
Comments				

Figure 25: Electric power network data rubric

Structure ID					
Structure Address	Name	Block	District	Colony	
Coordinates	Latitude		Longitude		
Plan dimension					
Typology	Water Front Structure				
	H< 10 m with Vs =250m/s	Cranes	Tanks	Other Cargo Facilities	Fuel Facilities
	H< 10 m with Vs =500m/s				Low Seismic
	H> 10 m with Vs =250m/s	stationary		stationary	Moderate Seismic
	H> 10 m with Vs =500m/s	rail mounted		rail mounted	High Seismic
Fixity			Anchored		Anchored
			Unanchored		Unanchored
Physical Codition	Structure Condition-Damage Grade				
	Grade-0	None			
	Grade-1	Slight			
	Grade-2	Moderate			
Comments					

Figure 26: Harbor System data rubric

Structure ID				
Structure Address	Name	Block	District	Colony
Coordinates	Latitude		Longitude	
Plan dimension				
Typology	Refineries		Pumping Plants	Tank Farm
	Small < 100000 BPD		Low Seismic	
	Medium/Large \geq 100000 BPD		High Seismic	
Fixity	Anchored		Anchored	Anchored
	Unanchored		Unanchored	Unanchored
Physical Codition	Structure Condition-Damage Grade			
	Grade-0	None		
	Grade-1	Slight		
	Grade-2	Moderate		
Comments				

Figure 27: Oil and Gas System data rubric

Structure ID					
Structure Address	Name	Block	District	Colony	
Coordinates	Latitude		Longitude		
Plan dimension					
Typology	Exchange Buildings	Transmission Tower			
Fixity	Anchored	Anchored			
	Unanchored	Unanchored			
Physical Codition	Structure Condition-Damage Grade				
	Grade-0	None			
	Grade-1	Slight			
	Grade-2	Moderate			
Comments					

Figure 28: Telecommunication network data rubric

Structure ID				
Structure Address	Name	Block	District	Colony
Coordinates	Latitude		Longitude	
Plan dimension				
Typology	Waste-Water treatment Plant		Water Treatment Plant	Pumping station
	Low rise low seismic			Small <10mgd
	Low rise advance seism			Medium/Large > 10mgd
Fixity	Anchored		Anchored	Anchored
	Unanchored		Unanchored	Unanchored
Physical Codition	Structure Condition-Damage Grade			
	Grade-0	None		
	Grade-1	Slight		
	Grade-2	Moderate		
Comments				

Figure 29: Water and Waste-Water Systems data rubric

In the second step, Geographic information system (GIS) mapping has been employed based on the typology classification for different existing structures shown in Figures 30-39. Also, the collected sample database shown in Tables 1-19.




Figure 30: Reinforced Concrete Building Stock in Case-study Area




Figure 31: Identified flyovers in the case-study area




Figure 32: Identified bridges in the case-study area




Figure 33: Power Grid-EPN-01




Figure 34: Generation Plant-EPN-02




Figure 35: Substations-EPN-03




Figure 36: Waterfront Structures, Cranes and Fuel Facilities




Figure 37: Refineries, Pumping Plants and Tank Farms




Figure 38: Telephone Exchange Buildings and Transmission Towers




Figure 39: Water treatment plant, Waste-water treatment plant and Pumping stations

Table 1: Ground plus Five Story Reinforced Concrete Buildings

S.No	Objectid	Location	Stoery	Building Type	Longitude	Latitude
1	8	Korangi	5	RCC	67.11277848	24.81620518
2	9	Korangi	5	RCC	67.11253342	24.81715338
3	10	Korangi	5	RCC	67.11343886	24.81642365
4	12	Korangi	5	RCC	67.12253902	24.80961462
5	13	Korangi	5	RCC	67.11845615	24.81380873
6	23	Korangi	5	RCC	67.14676254	24.81894782
7	28	Korangi	5	RCC	67.15981704	24.82608301
8	32	Korangi	5	RCC	67.16062797	24.82779414
9	33	Korangi	5	RCC	67.16086577	24.82782788
10	36	Korangi	5	RCC	67.1618926	24.82809204

Table 2: Ground plus Six Storeyed Reinforced Concrete Building

S.No	Objectid	Location	Stoery	Building Type	Longitude	Latitude
1	18	Korangi	6	RCC	67.11903532	24.81229
2	26	Korangi	6	RCC	67.14698993	24.8193
3	62	Clifton	6	RCC	67.03199123	24.83947
4	71	Clifton	6	RCC	67.02423376	24.82876
5	76	Clifton	6	RCC	67.03343144	24.83282
6	79	Clifton	6	RCC	67.03305869	24.83484
7	90	Clifton	6	RCC	67.0236973	24.83337
8	101	Clifton	6	RCC	67.02515405	24.83222
9	102	Clifton	6	RCC	67.02545056	24.83223
10	119	Clifton	6	RCC	67.02919081	24.8345

Table 3: Bent pier supported flyovers

S.No	Longitude	Latitude	Flyover name	Column Type
1	67.00714	24.84346	Mai Kalochi Flyover	Bent Pier
2	66.99553	24.8798	Liyari Flyover	Bent Pier
3	66.99435	24.88159	Liyari Flyovere	Bent Pier
4	67.03259	24.84092	Clifton Flyover	Bent Pier
5	66.98228	24.88925	SherShah Flyover	Bent Pier
6	66.96745	24.87594	Gulbai Flyover	Bent Pier
7	66.98334	24.83189	Napier Mole Flyover	Bent Pier

Table 4: Single column/Hammerhead pier supported flyovers

S.No	Longitude	Latitude	Flyover name	Column Type
1	66.99232	24.84559	MT khan flyover	Single Column Pier
2	66.99354	24.84681	Jinnah Flyover	Single Column Pier
3	67.08029	24.83062	Qayyumabad Interchange	Single Column Pier
4	67.07919	24.83056	Qayyumabad Interchange	Single Column Pier
5	67.08026	24.83009	Qayyumabad Interchange	Single Column Pier
6	67.04619	24.82208	Gizri Flyover	Single Column Pier

Table 5: Wall pier supported bridges

S.No	Latitude	Longitude	Bridge name	Column Type
1	24.83789	67.07787	Manzoor Colony Street Road Bridge 1	Wall Pier
2	24.8401	67.07794	Manzoor Colony Street Road Bridge 2	Wall Pier
3	24.80738	67.31679	Qasim Port Road Bridge 1	Wall Pier

Table 6: List of Low Voltage Transmission line-EPN-01

S.No	Longitude	Latitude	Capacity	Fixity
1	67.41255	24.81442	LV<150KV	Unanchored
2	67.41238	24.81102	LV<150KV	Unanchored
3	67.41227	24.81301	LV<150KV	Unanchored
4	67.41214	24.81513	LV<150KV	Unanchored
5	67.41203	24.81723	LV<150KV	Unanchored
6	67.41191	24.81932	LV<150KV	Unanchored
7	67.4125	24.80894	LV<150KV	Unanchored
8	67.41221	24.80857	LV<150KV	Unanchored
9	67.41364	24.79515	LV<150KV	Unanchored
10	67.39195	24.79023	LV<150KV	Unanchored

Table 7: List of Medium Voltage Transmission line-EPN-01

S.No	Longitude	Latitude	Capacity	Fixity
1	67.4373	24.81871	MV (350 KV to 150 KV)	Unanchored
2	67.43735	24.81763	MV (350 KV to 150 KV)	Unanchored

3	67.43602	24.81758	MV (350 KV to 150 KV)	Unanchored
4	67.43372	24.81745	MV (350 KV to 150 KV)	Unanchored
5	67.43133	24.81732	MV (350 KV to 150 KV)	Unanchored
6	67.42895	24.81722	MV (350 KV to 150 KV)	Unanchored
7	67.42657	24.8171	MV (350 KV to 150 KV)	Unanchored
8	67.42419	24.81699	MV (350 KV to 150 KV)	Unanchored
9	67.42181	24.81688	MV (350 KV to 150 KV)	Unanchored
10	67.41943	24.81677	MV (350 KV to 150 KV)	Unanchored

Table 8: List of Generation Plants-EPN-02

S.No	Name	Capacity	Fixity	Latitude	Longitude
1	K-Electric BQPS I	Small <200MW	Anchored	24.785	67.36
2	K-Electric BQPS II	Medium/large >200MW	Anchored	24.782	67.36
3	Port Qasim Power Plant	Medium/large >200MW	Anchored	24.785	67.37
4	Karachi Nuclear Power Complex	Medium/large >200MW	Anchored	24.845	66.789
5	DHA Cogen Ltd - DCL Power	Small <200MW	Anchored	24.749	67.083
6	KE KTPS (CCPP)	Medium/large >200MW	Anchored	24.786	67.138

Table 9: List of Substations-EPN-03

S.No	Name	Longitude	Latitude	Capacity	Fixity
1	Korangi South Grid Station	67.1694	24.8154	Low<150KV	Anchored
2	K-Electric EPZ Grid Station	67.2449	24.8295	Low<150KV	Anchored
3	PRL Grid Station	67.1258	24.8065	Low<150KV	Anchored
4	Defence Grid Station	67.0693	24.7945	Low<150KV	Anchored
5	KE DHA 1 Grid station	67.0758	24.7815	Low<150KV	Anchored
6	Korangi Creek Grid Station	67.0826	24.8297	Medium (150KV to 350KV)	Anchored
7	Gizri Grid Station	67.0521	24.8290	Medium (150KV to 350KV)	Anchored
8	KE KTPS Grid Station	67.1382	24.7852	Low<150KV	Anchored
9	KE Lalazar Grid Station	67.0102	24.8381	Medium (150KV to 350KV)	Anchored
10	Creek City Grid Station	67.0870	24.7800	Low<150KV	Anchored

Table 10: Waterfront Structures and Cranes

S.No	Name	Latitude	Longitude	Piers	Cranes
1	Boat Wharf	24.84087	66.98674	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
2	P.N.S Himalaya Pier	24.8192	66.95452	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
3	K.P.T. Crew Pier	24.8003	66.97409	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted

4	K.P.T. Officer Pier (Pilots)	24.79971	66.97453	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
5	K.P.T. Workshop Pier	24.80314	66.97183	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
6	Passenger Pier	24.80059	66.97366	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
7	Pak-Naval Academy Pier	24.80124	66.97332	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
8	Pier for public boats	24.80431	66.97038	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
9	Qasim Pier	24.79808	66.97584	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
10	Oil Pier I	24.80717	66.97852	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
11	Oil Pier II	24.81031	66.97642	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
12	Oil Pier III	24.81371	66.9751	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
13	Karachi Yacht Club Pier	24.81458	66.97559	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
14	Kemari Jetty	24.81678	66.97382	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
15	Port Grand Pier	24.84411	66.99176	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
16	FOTCO Jetty	24.79707	67.29423	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
17	Progas Jetty	24.80079	67.28767	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
18	Jetty	24.80088	67.28233	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
19	Pak-Steel Terminal (IOCB)	24.78388	67.3213	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
20	MVTJ Jetty	24.77179	67.3191	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
21	Service Jetty	24.77715	67.34651	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
22	LCT Pier	24.77439	67.34028	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
23	PAF Jetty	24.78321	67.13867	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
24	Jetty	24.79161	67.14861	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
25	Jetty	24.79027	67.14704	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
26	Jetty	24.78909	67.14646	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
27	Jetty	24.79016	67.14452	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
28	Jetty	24.78858	67.14385	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
29	Jetty	24.78829	67.14302	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
30	Jetty	24.78777	67.14165	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
31	Jetty	24.78603	67.14194	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
32	Jetty	24.78421	67.14128	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
33	DHA Creek Pier	24.78589	67.09134	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted
34	P. M. A Boat Jetty	24.85389	66.92987	H> 10m and Vs = 250m/sec	Stationery/Rail Mounted

Table 11: Cargo Handling Facilities, Steel Tanks and Fuel Facilities

S. No	Name	Cargo Handling Facilities	Tanks	Fuel Facilities
1	Boat Wharf	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
2	P.N.S Himalaya Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
3	K.P.T. Crew Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
4	K.P.T. Officer Pier (Pilots)	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
5	K.P.T. Workshop Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
6	Passenger Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
7	Pakistan Naval Academy Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
8	Pier for public boats	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
9	Qasim Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
10	Oil Pier I	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
11	Oil Pier II	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
12	Oil Pier III	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
13	Karachi Yacht Club Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
14	Kemari Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
15	Port Grand Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
16	FOTCO Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
17	Progas Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
18	Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
19	Pakistan Steel Terminal	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
20	MVTJ Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
21	Service Jetty	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)
22	LCT Pier	Stationery/Rail Mounted	Anchored	High Seismic (Unanchored)

Table 12: List of Oil Refineries

S.No	Name	Latitude	Longitude	Typology	Fixity
1	Khalis Oil refinery	24.80596	67.412752	Small	Anchored
2	HM Extraction	24.79174	67.402762	Small	Anchored
3	Mujahid Oil Refinery	24.7777	67.340117	Small	Anchored
4	Farooq Enterprises	24.80342	67.407858	Small	Anchored
5	M.M. Oil Mills	24.77477	67.332679	Small	Anchored
6	Unity Foods Ltd Portqasim Refinery Edible Oil	24.79504	67.401417	Small	Anchored
7	Shujabad Agro Industries	24.83265	67.297126	Small	Anchored
8	Gamalux Oleochemicals (PVT.) LTD.Director Number	24.83471	67.299155	Small	Anchored
9	Total Lube Pakistan (Lubricant Plant)	24.82348	67.287395	Small	Anchored
10	PARCO Bin Qasim	24.82526	67.305529	Medium/Large	Anchored

11	Al-Makka Oil Refinery	24.80198	67.405823	Small	Anchored
12	Mapak Edible Oils (Pvt.) Limited	24.78227	67.337145	Small	Anchored
13	Engineer's Lubricant (Lube Oil Plant)	24.82384	67.285775	Small	Anchored
14	PRL	24.80264	67.11685	Small	Anchored
15	PARCO KEAMARI TERMINAL	24.81543	66.989558	Medium/Large	Anchored
16	Faisalabad Oil Refinery	24.83518	67.294843	Small	Anchored
17	WR Edible Oil Refinery	24.83814	67.288583	Small	Anchored
18	Pakistan Refinery Limited	24.80115	67.119441	Small	Anchored
19	PARCO Corporate Headquarters	24.80415	67.135644	Small	Anchored
20	Bosicor Pakistan Ltd Refinery	24.81681	66.98455	Small	Anchored
21	IFFCO Pakistan	24.78134	67.335677	Small	Anchored
22	PSO Terminal	24.81802	66.989849	Small	Anchored
23	Chevron Pakistan Lubricants Pvt. Ltd	24.83936	66.97586	Small	Anchored
24	International Tank Terminals (Pvt.) Ltd	24.8411	66.976782	Small	Anchored
25	Haroon Oils Ltd	24.85056	66.982685	Small	Anchored
26	Chevron Oil Company	24.81938	66.988206	Small	Anchored
27	Byco Terminal Pakistan Ltd	24.81587	66.988166	Medium/Large	Anchored
28	Al Raheem Oil Terminal	24.81625	66.991014	Small	Anchored
29	Shell L O B P (Lubricant Oil Blending Plant)	24.81525	66.97677	Small	Anchored
30	Al Abbas Tank Terminal Kemari	24.81122	66.979332	Small	Anchored
31	Pakistan Molasses Company (pvt) Ltd.	24.81767	66.983308	Small	Anchored
32	Burshane Petroleum Pvt Limited	24.81779	66.984496	Small	Anchored
33	Pakistan State Oil (PSO) - Kemari Terminal A	24.81871	66.984715	Small	Anchored
34	Pak Grease Manufacturing Co (Pvt) Ltd	24.81845	66.984214	Small	Anchored
35	Total Parco Pakistan Ltd.	24.82014	66.989499	Small	Anchored
36	ZY & Co. Bulk Terminal (Pvt) LTD	24.81705	66.992214	Small	Anchored
37	Al Noor Terminal	24.81511	66.991895	Small	Anchored
38	F&B Terminal	24.81278	66.982258	Small	Anchored
39	Hascol Vito Terminal	24.82133	67.294688	Small	Anchored
40	Bakri Energy Oil Terminal	24.82665	67.301409	Small	Anchored
41	Bakri Energy MOGAS Terminal	24.82701	67.299676	Small	Anchored
42	Bakri Energy Oil Terminal 1	24.82546	67.303746	Small	Anchored
43	Hascol Petroleum Limited IPTL	24.82425	67.303715	Small	Anchored

Table 13: List of Pumping Plants

S.No	Name	Latitude	Longitude	Typology	Fixity
1	Khalis Oil refinery	24.80596	67.412752	High Seismic	Anchored
2	HM Extraction	24.79174	67.402762	High Seismic	Anchored
3	Mujahid Oil Refinery	24.7777	67.340117	High Seismic	Anchored
4	Farooq Enterprises	24.80342	67.407858	High Seismic	Anchored

5	M.M. Oil Mills	24.77477	67.332679	High Seismic	Anchored
6	Unity Foods Ltd Portqasim Refinery2 Edible Oil	24.79504	67.401417	High Seismic	Anchored
7	Shujabad Agro Industries	24.83265	67.297126	High Seismic	Anchored
8	Gamalux Oleochemicals (PVT.) LTD.Director Number	24.83471	67.299155	High Seismic	Anchored
9	Total Lube Pakistan (Lubricant Plant)	24.82348	67.287395	High Seismic	Anchored
10	PARCO Bin Qasim	24.82526	67.305529	High Seismic	Anchored
11	Al-Makka Oil Refinery	24.80198	67.405823	High Seismic	Anchored
12	Mapak Edible Oils (Pvt.) Limited	24.78227	67.337145	High Seismic	Anchored
13	Engineer's Lubricant (Lube Oil Plant)	24.82384	67.285775	High Seismic	Anchored
14	PRL	24.80264	67.11685	High Seismic	Anchored
15	PARCO KEAMARI TERMINAL	24.81543	66.989558	High Seismic	Anchored
16	Faisalabad Oil Refinery	24.83518	67.294843	High Seismic	Anchored
17	WR Edible Oil Refinery	24.83814	67.288583	High Seismic	Anchored
18	Pakistan Refinery Limited	24.80115	67.119441	High Seismic	Anchored
19	PARCO Corporate Headquarters	24.80415	67.135644	High Seismic	Anchored
20	Bosicor Pakistan Ltd Refinery	24.81681	66.98455	High Seismic	Anchored
21	IFFCO Pakistan	24.78134	67.335677	High Seismic	Anchored
22	PSO Terminal"C"	24.81802	66.989849	High Seismic	Anchored
23	Chevron Pakistan Lubricants Pvt. Ltd	24.83936	66.97586	High Seismic	Anchored
24	International Tank Terminals (Pvt.) Ltd	24.8411	66.976782	High Seismic	Anchored
25	Haroon Oils Ltd	24.85056	66.982685	High Seismic	Anchored
26	Chevron Oil Company	24.81938	66.988206	High Seismic	Anchored
27	Byco Terminal Pakistan Ltd	24.81587	66.988166	High Seismic	Anchored
28	Al Raheem Oil Terminal	24.81625	66.991014	High Seismic	Anchored
29	Shell L O B P (Lubricant Oil Blending Plant)	24.81525	66.97677	High Seismic	Anchored
30	Al Abbas Tank Terminal Kemari	24.81122	66.979332	High Seismic	Anchored
31	Pakistan Molasses Company (pvt) Ltd.	24.81767	66.983308	High Seismic	Anchored
32	Burshane Petroleum Pvt Limited	24.81779	66.984496	High Seismic	Anchored
33	Pakistan State Oil (PSO) - Kemari Terminal A	24.81871	66.984715	High Seismic	Anchored
34	Pak Grease Manufacturing Co (Pvt) Ltd	24.81845	66.984214	High Seismic	Anchored
35	Total Parco Pakistan Ltd.	24.82014	66.989499	High Seismic	Anchored
36	ZY & Co. Bulk Terminal (Pvt) LTD	24.81705	66.992214	High Seismic	Anchored
37	Al Noor Terminal	24.81511	66.991895	High Seismic	Anchored
38	F&B Terminal	24.81278	66.982258	High Seismic	Anchored
39	Hascol Vito Terminal	24.82133	67.294688	High Seismic	Anchored
40	Bakri Energy Oil Terminal	24.82665	67.301409	High Seismic	Anchored
41	Bakri Energy MOGAS Terminal	24.82701	67.299676	High Seismic	Anchored
42	Bakri Energy Oil Terminal 1	24.82546	67.303746	High Seismic	Anchored
43	Hascol Petroleum Limited IPTL	24.82425	67.303715	High Seismic	Anchored

Table 14: Tank Farms

S.No	Name	Latitude	Longitude	Fixity
1	Khalis Oil refinery	24.80596	67.412752	Anchored
2	HM Extraction	24.79174	67.402762	Anchored
3	Mujahid Oil Refinery	24.7777	67.340117	Anchored
4	Farooq Enterprises	24.80342	67.407858	Anchored
5	M.M. Oil Mills	24.77477	67.332679	Anchored
6	Unity Foods Ltd Portqasim Refinery2 Edible Oil	24.79504	67.401417	Anchored
7	Shujabad Agro Industries	24.83265	67.297126	Anchored
8	Gamalux Oleochemicals (PVT.) LTD.Director Number	24.83471	67.299155	Anchored
9	Total Lube Pakistan (Lubricant Plant)	24.82348	67.287395	Anchored
10	PARCO Bin Qasim	24.82526	67.305529	Anchored
11	Al-Makka Oil Refinery	24.80198	67.405823	Anchored
12	Mapak Edible Oils (Pvt.) Limited	24.78227	67.337145	Anchored
13	Engineer's Lubricant (Lube Oil Plant)	24.82384	67.285775	Anchored
14	PRL	24.80264	67.11685	Anchored
15	PARCO KEAMARI TERMINAL	24.81543	66.989558	Anchored
16	Faisalabad Oil Refinery	24.83518	67.294843	Anchored
17	WR Edible Oil Refinery	24.83814	67.288583	Anchored
18	Pakistan Refinery Limited	24.80115	67.119441	Anchored
19	PARCO Corporate Headquarters	24.80415	67.135644	Anchored
20	Bosicor Pakistan Ltd Refinery	24.81681	66.98455	Anchored
21	IFFCO Pakistan	24.78134	67.335677	Anchored
22	PSO Terminal“C”	24.81802	66.989849	Anchored
23	Chevron Pakistan Lubricants Pvt. Ltd	24.83936	66.97586	Anchored
24	International Tank Terminals (Pvt.) Ltd	24.8411	66.976782	Anchored
25	Haroon Oils Ltd	24.85056	66.982685	Anchored
26	Chevron Oil Company	24.81938	66.988206	Anchored
27	Byco Terminal Pakistan Ltd	24.81587	66.988166	Anchored
28	Al Raheem Oil Terminal	24.81625	66.991014	Anchored
29	Shell L O B P (Lubricant Oil Blending Plant)	24.81525	66.97677	Anchored
30	Al Abbas Tank Terminal Kemari	24.81122	66.979332	Anchored
31	Pakistan Molasses Company (pvt) Ltd.	24.81767	66.983308	Anchored
32	Burshane Petroleum Pvt Limited	24.81779	66.984496	Anchored
33	Pakistan State Oil (PSO) - Kemari Terminal A	24.81871	66.984715	Anchored
34	Pak Grease Manufacturing Co (Pvt) Ltd	24.81845	66.984214	Anchored
35	Total Parco Pakistan Ltd.	24.82014	66.989499	Anchored
36	ZY & Co. Bulk Terminal (Pvt) LTD	24.81705	66.992214	Anchored
37	Al Noor Terminal	24.81511	66.991895	Anchored
38	F&B Terminal	24.81278	66.982258	Anchored
39	Hascol Vito Terminal	24.82133	67.294688	Anchored

40	Bakri Energy Oil Terminal	24.82665	67.301409	Anchored
41	Bakri Energy MOGAS Terminal	24.82701	67.299676	Anchored
42	Bakri Energy Oil Terminal 1	24.82546	67.303746	Anchored
43	Hascol Petroleum Limited IPTL	24.82425	67.303715	Anchored

Table 15: Telephone Exchange Buildings

S.No	Name	Latitude	Longitude	Fixity
1	Telephone Exchange	24.826262	67.176839	Anchored
2	Maripur Telephone Exchange	24.866197	66.917705	Anchored
3	Clifton Telephone Exchange	24.813771	67.029837	Anchored
4	PTCL Misri Shah Telephone Exchange	24.801364	67.066752	Anchored
5	Karachi Telephone Exchange	24.844178	67.030615	Anchored
6	PTCL Telephone Exchange	24.843297	67.006948	Anchored
7	PTCL, Telephone Exchange	24.849667	67.002288	Anchored

Table 16: List of Transmission Towers

Tower-No	Latitude	Longitude	Fixity
1	24.828807	67.060841	Anchored
2	24.830647	67.06192	Anchored
3	24.78447	67.346878	Anchored
4	24.78447	67.346878	Anchored
5	24.78447	67.346878	Anchored
6	24.821548	67.065353	Anchored
7	24.821548	67.065353	Anchored
8	24.821548	67.065353	Anchored
9	24.833908	67.066727	Anchored
10	24.833908	67.066727	Anchored

Table 17: Water Treatment Plant

S.No	Name	Fixity	Latitude	Longitude
1	Bahria Foundation Water Purification Plant	Anchored	24.82436	67.04179
2	CBC Water Purification Plant 02	Anchored	24.78944	67.04507
3	CBC Water Purification Plant 01	Anchored	24.78324	67.05071
4	CBC Water Purification Plant 03	Anchored	24.79395	67.04409

Table 18: Waste-Water Treatment Plant

S.No	Name	Latitude	Longitude	Typology	Fixity
------	------	----------	-----------	----------	--------

1	TP-3	24.86111	66.95222	Low Rise Advance Seismic	Anchored
2	TP-1	24.90023	67.00367	Low Rise Advance Seismic	Anchored
3	TP-2	24.85122	67.07043	Low Rise Advance Seismic	Anchored
4	DHA Waste Water TP	24.77421	67.09344	Low Rise Advance Seismic	Anchored

Table 19: List of Pumping Stations (PS)

S.No	Name	Latitude	Longitude	Typology	Fixity
1	Gulbai PS	24.876665	66.966431	Small	Anchored
2	Bihar Colony PS	24.874931	66.985255	Small	Anchored
3	Chakawara PS	24.876154	66.996614	Small	Anchored
4	Peoples Play Ground PS	24.859232	66.987508	Small	Anchored
5	Khajoor Bazar PS	24.859281	67.00035	Small	Anchored
6	Shah Waliullah PS	24.854119	66.994556	Small	Anchored
7	Gao Gall PS	24.855253	66.998491	Small	Anchored
8	Musa Lane PS	24.854429	66.996966	Small	Anchored
9	Jafar Uddin PS	24.852528	66.993567	Small	Anchored
10	Bombay Bazar PS	24.852808	67.001027	Small	Anchored

In the third step, PGA has been extracted from the hazard analysis presented in a separate report, which has been reproduced in Figure 40. The extracted PGA obtained at bed-rock level is further amplified on the basis of site amplification factors (Table 20) considering the typical soil characteristics (i.e., Soil type SD of UBC-97) in the case study area (Figure 41). The calculated soil amplification factor used in this report is 1.4 and is based on the calculated mean value of peak ground acceleration for different probability of exceedance (Table 21).




Figure 40: Spatial Distribution for annual probability of exceedance of the ground motion in terms of PGA-intensity measure in 50 years (a) 70 percent probability of exceedance (53 YRP) (b) 50 percent probability of

exceedance (80 YRP) (c) 25 percent probability of exceedance (178 YRP) (d) 10 percent probability of exceedance (476 YRP) (e) 5 percent probability of exceedance (976 YRP) (f) 2 percent probability of exceedance (2475 YRP)




Figure 41: Vs30 values in Case-study area (Kumar et al., 2015)

Table 20: Soil Amplification Factors as per UBC-97

Soil Profile Type	Coefficient C_a				
	$Z=0.075$	$Z=0.15$	$Z=0.2$	$Z=0.3$	$Z=0.4$
S_A	0.06	0.12	0.16	0.24	$0.32N_a$
S_B	0.08	0.15	0.20	0.30	$0.40N_a$
S_C	0.09	0.18	0.24	0.33	$0.40N_a$
S_D	0.12	0.22	0.28	0.36	$0.44N_a$
S_E	0.19	0.30	0.34	0.36	$0.36N_a$
	Coefficient C_v				
	$Z=0.075$	$Z=0.15$	$Z=0.2$	$Z=0.3$	$Z=0.4$
S_A	0.06	0.12	0.16	0.24	$0.32N_v$
S_B	0.08	0.15	0.20	0.30	$0.40N_v$
S_C	0.13	0.25	0.32	0.45	$0.56N_v$
S_D	0.18	0.32	0.40	0.54	$0.64N_v$
S_E	0.26	0.50	0.64	0.84	$0.96N_v$

Table 21: Calculated Mean value of Intensity Measure-PGA for Different Return Periods

Return Period (years)	53	80	178	476	976	2475
Probability of exceedance (POE) (%)	70%	50%	25%	10%	5%	2%
PGA (g)	0.166	0.197	0.268	0.377	0.474	0.623

In the fourth and final step, the suitable fragility curves are identified from the literature and the corresponding damage matrices for different structures have been plotted. The fragility functions proposed by FEMA loss estimation methodology for earthquake models (FEMA-HAZUS Technical manual-2003) have been used in this report for damage estimates in all building type except for low-rise C3 and low-rise URM buildings Kumar et al., 2017 and Naveed et al., 2014 proposed fragility functions have been employed. To estimate the damage in bridges and flyovers for study area Khan et al., 2015 proposed fragility functions are employed. For electric power network system, the fragility functions proposed by FEMA loss estimation methodology for earthquake models (FEMA-HAZUS Technical manual-2003) have been employed.

The empirical fragility curves describing the earthquake induced damage in port structures proposed by HAZUS (NIBS-2004) methodology have been employed. Damage functions for waterfront structures were established based on damageability of subcomponents, namely, piers, seawalls, and wharf. Fault tree logic and the lognormal best fitting technique were used in developing these fragility curves. For cranes and cargo handling equipment, a distinction is made between stationary and rail-mounted cranes. Similar to waterfront structures, damage functions for fuel facilities were established based on damageability of subcomponents, namely, building structure (high seismic/low seismic), tanks (anchored/unanchored), and backup power (with/without). Fault-tree logic and the lognormal best fitting technique were used in developing these fragility curves. For oil refineries, the employed fragility curves are based on the probabilistic combination of subcomponent damage functions using Boolean expressions to describe the relationship of subcomponents. For pumping plants, the fragility function proposed by the Risk-UE Project (Alexoudi and Petilakis, 2003) for anchored and unanchored components have been used. Finally, the fragility functions proposed by HAZUS (NIBS 2004) are employed for the vulnerability assessment of tank farms. These fragility functions are based on fault-tree analysis (Figure 42) accounting also the fragility of the equipment (electric power, tanks, elevated pipes, electrical and mechanical components) needed for the tank facility to function properly.




Figure 42: Fault-tree analysis proposed by HAZUS (NIBS 2004) for tank farms

The fragility functions from SRM-LIFE (2007) (Seismic Risk Assessment and Management of Lifelines, Utilities and Infrastructures) are employed for the vulnerability assessment of water and waste-water system. They were derived through fault-tree analysis, using the fault-tree and the fragility curves of sub-components proposed by HAZUS (NIBS 2004). The general framework of the methodology adopted in SRM-LIFE (2007) is illustrated in Figure 43. The vulnerability of buildings and lifeline systems is assessed for different seismic scenarios (Pitilakis et al., 2006a,b; Pitilakis et al., 2007a,b; Argyroudis et al., 2005).




Figure 43: Seismic Risk Mitigation approach for lifelines and infrastructures

In this report, to develop the damage matrices for different inventories generally HAZUS methodology has been employed. The HAZUS-MH Earthquake Model provides estimates of damage and loss to buildings, essential facilities, transportation lifelines, utility lifelines, and population based on scenario or probabilistic earthquakes. The HAZUS model employs both earthquake hazard and structural fragility terms to calculate damage ratios and estimate damage costs (Figure 44).




Figure 44: Earthquake Loss estimation Methodology (FEMA-HAZUS Technical manual-2003)

Chapter 7 – Results and Discussion

The fragility functions for C1 building are plotted (Figures 45-47) for low-rise (C1L- number of floors three), mid-rise (C1M-number of floors four to eight) and high-rise (C1H- number of floors more than eight) building stock in terms of intensity measure (IM) PGA. Results are presented in terms of damage matrices in Figures 48-50. These show that at 10% probability of exceedance event, for low-rise structures 13% slight, 34% moderate, 31% extensive and 13% collapse limit states exceeding. For mid-rise structures 13% slight, 48% moderate, 25% extensive and 9% collapse limit states exceeding. In case of high-rise structures, 10% slight, 43% moderate, 30% extensive and 14% collapse limit states exceeding. The detailed damage matrices for different probability of exceedance are shown in Tables 22-24 for the low-rise, mid-rise and high-rise moment resisting framed buildings.




Figure 45: Fragility Curves for Low-rise Reinforced Concrete Moment Frame (C1L)




Figure 46: Fragility Curves for Mid-rise Reinforced Concrete Moment Frame (C1M)




Figure 47: Fragility Curves for High-rise Reinforced Concrete Moment Frame (C1H)

Table 22: Damage Matrix for Low-rise Concrete Moment Resisting Framed Buildings (C1L)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	48	21	23	7	1	100
80	37	23	27	11	2	100
178	21	19	34	21	5	100
476	9	13	34	31	13	100
976	4	9	28	37	22	100
2475	2	4	20	37	37	100

Table 23: Damage Matrix for Mid-rise Concrete Moment Resisting Framed Buildings (C1M)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	36	29	31	4	0	100
80	26	28	38	7	1	100
178	13	22	47	15	3	100
476	5	13	48	25	9	100
976	2	8	42	32	16	100
2475	1	3	31	36	29	100

Table 24: Damage Matrix for High-rise Concrete Moment Resisting Framed Buildings (C1H)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	26	29	37	7	1	100
80	18	26	43	11	2	100
178	8	18	48	20	6	100
476	3	10	43	30	14	100
976	1	6	34	35	24	100
2475	0	3	23	35	39	100




Figure 48: Low-rise Concrete Moment Resisting Framed Buildings (C1L)




Figure 49: Mid-rise Concrete Moment Resisting Framed Buildings (C1M)

Damage Matrix for C1H




Figure 50: High-rise Concrete Moment Resisting Framed Buildings (C1H)

The fragility functions for C2 buildings are plotted (Figures 51-53) for low-rise (C2L- number of floors three), mid-rise (C2M-number of floors four to eight) and high-rise (C2H- number of floors more than eight) building stock in terms of intensity measure PGA. Results are presented in terms of damage matrices in Figures 54-56. These show that at 10% probability of exceedance event, for low-rise structures 24% slight, 29% moderate, 25% extensive and 9% collapse limit states exceeding. For mid-rise structures 20% slight, 45% moderate, 21% extensive and 6% collapse limit states exceeding. In case of high-rise structures, 18% slight, 52% moderate, 21% extensive and 5% collapse limit states exceeding. The detailed damage matrices for different probability of exceedance are shown in Tables 25-27 for the low-rise, mid-rise and high-rise shear wall framed buildings.




Figure 51: Fragility Functions for Low-rise Shear Wall Framed Building (C2L)




Figure 52: Fragility Functions for Mid-rise Shear Wall Framed Building (C2M)




Figure 53: Fragility Functions for High-rise Shear Wall Framed Building (C2H)

Table 25: Damage Matrix for Low-rise Shear Wall Framed Buildings (C2L)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	55	27	13	5	0	100
80	44	30	18	7	1	100
178	26	31	25	15	3	100
476	13	24	29	25	9	100
976	7	17	28	31	17	100
2475	3	10	22	35	30	100

Table 26: Damage Matrix for Mid-rise Shear Wall Framed Buildings (C2M)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	44	32	21	3	0	100
80	34	33	28	4	1	100
178	18	30	39	11	2	100

476	8	20	45	21	6	100
976	4	13	42	29	12	100
2475	1	8	33	36	22	100

Table 27: Damage Matrix for High-rise Shear Wall Framed Buildings (C2H)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	31	38	28	3	0	100
80	22	38	35	5	0	100
178	10	30	48	10	2	100
476	4	18	52	21	5	100
976	2	11	48	29	10	100
2475	0	6	38	36	20	100




Figure 54: Damage Matrix for Low-rise Shear Wall Framed Building (C2L)

Damage Matrix for C2M




Figure 55: Damage Matrix for Mid-rise Shear Wall Framed Building (C2M)

Damage Matrix for C2H




Figure 56: Damage Matrix for High-rise Shear Wall Framed Building (C2H)

The fragility functions (Figures 57-59) corresponding to C3 buildings are plotted for low-rise (C3L- number of floors three), mid-rise (C3M- number of floors four to eight) and high-rise (C3H- number of floors more than eight) building stock. Results are presented in terms of damage matrices in Figures 60-62. These show that at 10% probability of exceedance event, for low-rise structures 2% slight, 3% moderate, 7% extensive and 85% collapse limit states exceeding. For mid-rise structures 5% slight, 20% moderate, 30% extensive and 44% collapse limit states exceeding. In case of high-rise structures, 4% slight, 26% moderate, 28% extensive and 41% collapse limit states exceeding. The detailed damage matrices for different probability

of exceedance are shown in Tables 28-30 for the low-rise, mid-rise and high-rise infilled framed buildings.




Figure 57: Fragility Functions for Low-rise Infilled Framed Building (C3L)




Figure 58: Fragility Functions for Mid-rise Infilled Framed Building (C3M)




Figure 59: Fragility Functions for High-rise Infilled Framed Building (C3H)

Table 28: Damage Matrix for Low-rise Infilled Framed Buildings (C3L)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	28	9	7	15	41	100
80	20	7	7	15	51	100
178	9	5	4	12	70	100
476	3	2	3	7	85	100
976	1	1	2	4	92	100
2475	0	1	0	2	97	100

Table 29: Damage Matrix for Mid-rise Infilled Framed Buildings (C3M)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	17	23	34	18	8	100
80	11	19	35	22	13	100
178	4	11	30	29	26	100
476	1	5	20	30	44	100
976	0	3	13	25	59	100
2475	0	1	7	18	74	100

Table 30: Damage Matrix for High-rise Infilled Framed Buildings (C3H)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	13	22	43	15	7	100
80	8	18	43	20	11	100
178	3	10	37	27	23	100
476	1	4	26	28	41	100
976	0	2	17	25	56	100
2475	0	1	9	18	72	100




Figure 60: Damage Matrix for Low-rise Infilled Framed Building (C3L)




Figure 61: Damage Matrix for Mid-rise Infilled Framed Building (C3M)




Figure 62: Damage Matrix for High-rise Infilled Framed Building (C3H)

The fragility functions (Figures 63-64) for URM buildings are plotted for unreinforced stone masonry (Cst) and unreinforced block masonry (Cbl) building stock. Results are presented in terms of damage matrices in Figures 65-67. These show that at 10% probability of exceedance event, for stone masonry structures 8% slight, 20% moderate, 38% extensive and 33% collapse limit states exceeding. For block masonry structures 13% slight, 23% moderate, 39% extensive and 23% collapse limit states exceeding. The detailed damage matrices for different probability of exceedance are shown in Tables 31-32 for the stone masonry and block masonry buildings.




Figure 63: Fragility Functions for Unreinforced Stone Masonry Building (Cst)




Figure 64: Fragility Functions for Unreinforced Block Masonry Building (Cbl)

Table 31: Damage Matrix for Unreinforced Stone Masonry Buildings (Cst)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	15	37	27	17	4	100
80	10	30	30	24	6	100
178	3	19	28	34	16	100
476	1	8	20	38	33	100
976	0	4	13	35	48	100
2475	0	2	6	26	66	100

Table 32: Damage Matrix for Unreinforced Block Masonry Buildings (Cbl)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	23	39	23	13	2	100
80	15	36	27	18	4	100
178	6	25	28	31	10	100
476	2	13	23	39	23	100
976	1	7	16	39	37	100
2475	0	3	9	33	55	100




Figure 65: Damage Matrix for Unreinforced Stone Masonry Buildings




Figure 66: Damage Matrix for Unreinforced Block Masonry Buildings

Bridges and flyovers are classified on the basis of pier typologies in this report. The fragility curves presented by Khan et al. (2015) are employed for the vulnerability assessment of these structures. These were derived through pushover analysis at component levels. Four different damage states such as slight, moderate, extensive and collapse are considered herein and their corresponding fragility curves are presented in Figures 67-69. Results are presented in terms of damage matrices in Figures 70-72. These show that 13% slight, 13% moderate, 18% extensive and 55% collapse limit states may exceed in single column pier supported structures at 10% probability of exceedance event. Similarly, 18% slight, 4% moderate, 14% extensive and 61% collapse limit states may exceed in multiple columns/bent pier supported structures at 10% probability of exceedance. Finally, at the same probability of exceedance 30% slight, 13% moderate, 14% extensive and 15% collapse limit states may exceed in the wall pier supported structures. The detailed damage matrices for different probability of exceedance are shown in Tables 33-35 for the single column pier, multiple column pier and wall pier bridges.




Figure 67: Fragility Functions for Single Column Pier




Figure 68: Fragility Functions for Multiple Columns Pier




Figure 69: Fragility Functions for Wall Pier

Table 33: Damage Matrix for Single Column Pier

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	23	39	15	12	11	100
80	15	35	17	15	17	100
178	6	24	17	19	33	100
476	2	13	13	18	55	100
976	1	7	8	15	70	100
2475	0	3	4	9	83	100

Table 34: Damage Matrix for Multiple Columns Pier

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	29	41	4	11	14	100
80	20	40	5	13	22	100
178	9	31	5	16	40	100
476	3	18	4	14	61	100
976	1	10	3	11	75	100

2475	0	4	1	7	87	100
-------------	---	---	---	---	----	-----

Table 35: Damage Matrix for Wall Pier

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	78	16	3	2	1	100
80	69	21	5	3	2	100
178	49	29	9	8	6	100
476	28	30	13	14	15	100
976	17	26	14	17	26	100
2475	8	18	12	19	43	100




Figure 70: Damage Matrix for Single Column Pier




Figure 71: Damage Matrix for Multiple Columns Pier




Figure 72: Damage Matrix for Wall Pier

The fragility functions for EPN-01 are plotted for two cases; (1) for collapse limit state (Figure 73) and (2) for functionality or connectivity loss (Figure 77). These fragility curves are based on empirical approach proposed by Osorio et al., 2007. Results are presented in terms of damage matrices in Figures 74-76. These show that for collapse limit state around 34% low voltage, 56% medium voltage and 96% high voltage transmission lines will be damaged at 10% probability of exceedance event. The detailed damage matrix for different probability of exceedance is shown in Table 36 for the low voltage, medium voltage and high voltage

transmission lines. Fragility functions based on functionality loss show that 100% probability of 80% connectivity loss in all three types of transmission lines (Figures 78-80) at 10% probability of exceedance event. The detailed damage matrix for different probability of exceedance is shown in Table 37 for the 20%, 50% and 80% functionality loss.




Figure 73: Collapse limit state for EPN-01

Table 36: Damage Matrix for Collapse limit state (EPN-01)

Return Period	Low Voltage		Medium Voltage		High Voltage	
	None	Collapse	None	Collapse	None	Collapse
Years	%	%	%	%	%	%
53	99	1	96	4	70	30
80	97	3	91	9	52	48
178	88	12	73	27	20	80
476	66	34	44	56	4	96
976	45	55	24	76	1	99
2475	23	77	8	92	0	100




Figure 74: Damage Matrix for Collapse limit state for EPN-01 with Low Voltage Transmission lines




Figure 75: Damage Matrix for Collapse limit state for EPN-01 with Medium Voltage Transmission lines




Figure 76: Damage Matrix for Collapse limit state for EPN-01 with High Voltage Transmission lines




Figure 77: Fragility Functions in terms of Connectivity Loss (EPN-01)

Table 37: Damage Matrix for Connectivity Loss (EPN-01)

Return Period	20% CL		50% CL		80% CL	
	None	Collapse	None	Collapse	None	Collapse
Years	%	%	%	%	%	%
53	1	99	99	1	100	0
80	0	100	80	20	99	1
178	0	100	1	99	29	71
476	0	100	0	100	0	100
976	0	100	0	100	0	100
2475	0	100	0	100	0	100




Figure 78: Damage Matrix in terms of 20% Connectivity Loss (EPN-01)




Figure 79: Damage Matrix in terms of 50% Connectivity Loss (EPN-01)




Figure 80: Damage Matrix in terms of 80% Connectivity Loss (EPN-01)

Generation plants (EPN-02) are classified into small and medium/large generation plants. The fragility curves for EPN-02 are presented for damage states i.e., slight, moderate, extensive and collapse limit states (Figures 81-82). These fragility curves are based on numerical method and proposed by FEMA-HAZUS technical manual in 2003. Results are presented in terms of damage matrix in Figure 83 and show that anchored small generation plants exceeding 14% slight, 54% moderate, 24% extensive and 7% collapse limit states at 10% probability of

exceedance event. Similarly, for anchored medium/large generation plants show that (Figure 84) 24% slight, 47% moderate, 22% extensive and 5% collapse limit states exceeding at 10% probability of exceedance. The detailed damage matrices for variant probability of exceedance are shown in Tables 38-39 for the anchored small, medium and large generation plants.




Figure 81: Fragility Functions for Anchored-Small Generation Plant (EPN-02)




Figure 82: Fragility Functions for Anchored-Medium/Large Generation Plant (EPN-02)

Table 38: Damage Matrix for Anchored Small Generation Plant (EPN-02)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	18	49	32	2	0	100
80	11	44	42	3	0	100
178	4	29	55	11	2	100
476	1	14	54	24	7	100
976	0	7	44	33	16	100
2475	0	2	28	37	33	100

Table 39: Damage Matrix for Anchored Medium/Large Generation Plant (EPN-02)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	20	55	23	2	0	100
80	13	53	31	4	0	100
178	5	40	43	10	1	100
476	1	24	47	22	5	100
976	0	14	42	32	11	100
2475	0	6	31	39	24	100




Figure 83: Fragility Functions for Anchored Small Generation Plant (EPN-02)




Figure 84: Fragility Functions for Anchored-Medium/Large Generation Plant (EPN-02)

Substations (EPN-03) are classified into low, medium and high voltage substations. The fragility curves for EPN-03 are presented for damage states i.e., slight, moderate, extensive and collapse limit states (Figures 85-87). These fragility curves are based on numerical method and proposed by FEMA-HAZUS technical manual in 2003. Results are presented in terms of damage matrix in Figure 88 and show that anchored low voltage substations exceeding 23% slight, 34% moderate, 31% extensive and 3% collapse limit states. Similarly, results (Figure 89) for anchored medium voltage substations show that 15% slight, 22% moderate, 51% extensive and 6% collapse limit states. Finally, for anchored high voltage substation show that (Figure 90) 1% slight, 2% moderate, 68% extensive and 28% collapse limit states exceeding at 10% probability of exceedance event. The detailed damage matrices for different probability of exceedance are shown in Tables 40-42 for the anchored low, medium and large substations.




Figure 85: Fragility Functions for Anchored-Low Voltage Substation (EPN-03)




Figure 86: Fragility Functions for Anchored-Medium Voltage Substation (EPN-03)




Figure 87: Fragility Functions for Anchored-High Voltage Substation (EPN-03)

Table 40: Damage Matrix for Anchored Low Voltage Substation (EPN-03)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	44	40	14	1	0	100
80	35	41	21	3	0	100
178	20	35	32	12	0	100
476	10	23	34	31	3	100
976	5	14	27	47	8	100
2475	2	6	15	56	21	100

Table 41: Damage Matrix for Anchored Medium Voltage Substation (EPN-03)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	43	36	18	3	0	100
80	32	36	24	7	0	100
178	16	28	30	25	1	100
476	6	15	22	51	6	100
976	3	7	12	61	16	100
2475	1	3	4	54	39	100

Table 42: Damage Matrix for Anchored High Voltage Substation (EPN-03)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	21	21	29	29	0	100
80	12	15	24	47	1	100
178	4	6	10	72	8	100
476	1	1	2	68	28	100
976	0	0	0	48	51	100
2475	0	0	0	24	76	100




Figure 88: Damage Matrix for Anchored-Low Voltage Substation (EPN-03)




Figure 89: Damage Matrix for Anchored-Medium Voltage Substation (EPN-03)




Figure 90: Damage Matrix for Anchored-High Voltage Substation (EPN-03)

In HAZUS methodology, waterfront structures are categorised on the basis of height (H) of structure and the site specific shear wave velocity (V_s). The height of waterfront structures is more than 10m and the average shear wave velocity is around 300m/sec (close to 260m/sec) has been considered in this report. Based on this the fragility functions (Figure 91) proposed by HAZUS methodology for $H > 10\text{m}$ and $V_s = 260\text{m/sec}$ are employed herein for four different damage states such as slight, moderate, extensive and collapse limit states. Results are

presented in terms of damage matrix (Figure 92) and show that 61% slight, 34% moderate and 3% extensive limit states exceeding at 10% probability of exceedance event. The detailed damage matrix for different probability of exceedance is shown in Table 43.




Figure 91: Fragility Functions for Waterfront Structures

Table 43: Damage Matrix for Waterfront Structures

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	36	61	2	0	0	100
80	24	71	5	0	0	100
178	9	75	15	0	0	100
476	2	61	34	3	0	100
976	1	43	49	7	0	100
2475	0	24	57	19	0	100




Figure 92: Damage Matrix for Waterfront Structures

Cranes and cargo handling equipment are classified into stationery and unanchored rail mounted equipment. The fragility curves for stationery and unanchored rail mounted equipment are presented for damage states i.e., slight, moderate and extensive limit states shown in Figures 93-94. Results are presented in terms of damage matrices (Figures 95-96) and show that stationery equipment exceeding 33% slight, 23% moderate and 8% extensive limit states. Rail mounted equipment exceeding 39% slight, 41% moderate and 14% extensive limit states. The detailed damage matrices for different probability of exceedance are shown in Tables 44-45.




Figure 93: Fragility function for Stationery Equipment




Figure 94: Fragility function for Rail Mounted Equipment

Table 44: Damage Matrix for Stationery Equipment

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	84	13	3	1	0	100
80	76	18	5	1	0	100
178	57	28	12	3	0	100
476	36	33	23	8	0	100
976	22	31	32	14	0	100
2475	11	25	39	25	0	100

Table 45: Damage Matrix for Rail Mounted Equipment

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	43	46	9	1	0	100
80	32	51	15	2	0	100
178	16	50	27	6	0	100
476	6	39	41	14	0	100
976	3	28	47	23	0	100

2475	1	16	47	36	0	100
-------------	----------	-----------	-----------	-----------	----------	------------




Figure 95: Damage Matrix for Stationary Equipment




Figure 96: Damage Matrix for Rail Mounted Equipment

Fuel facilities are categorised into low seismic and high seismic building structures with anchored and unanchored components. The fragility curves (Figure 97) for unanchored high seismic buildings are presented for damage states of, slight, moderate, extensive and collapse limit states. Results show that (Figure 98) fuel facilities for unanchored high seismic buildings

with backup power system exceeding 23% slight, 54% moderate, 14% extensive and 7% collapse limit states. The detailed damage matrix for different probability of exceedance is shown in Table 46.




Figure 97: Fragility Functions for Fuel Facilities (High Seismic Building with Unanchored Components)

Table 46: Damage Matrix for Fuel Facilities (High Seismic Building with Unanchored Components)

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	37	47	15	1	0	100
80	25	49	23	2	1	100
178	9	41	41	6	2	100
476	2	23	54	14	7	100
976	1	12	53	19	14	100
2475	0	5	44	24	27	100




Figure 98: Damage Matrix for Fuel Facilities (High Seismic Building with Unanchored Components)

Refineries are categorized into small and medium/large oil refineries in this report. Further classification of these is based upon anchored and unanchored components. Four different damage states such as slight, moderate, extensive and collapse are considered herein and their corresponding fragility curves are shown in Figures 99-100. Results are presented in terms of damage matrices (Figures 101-102) and show that for anchored small oil refineries 42% slight, 7% moderate, 12% extensive and 7% collapse limit states exceeding at 10% probability of exceedance event. Similarly, for anchored medium/large oil refineries show that 34% slight, 12% moderate, 2% extensive and 0% collapse limit states exceeding at 10% probability of exceedance event. The detailed damage matrices for different probability of exceedance are shown in Tables 47-48.




Figure 99: Fragility Functions for Small Oil Refineries with Anchored Components




Figure 100: Fragility Functions for Medium/Large Oil Refineries with Anchored Components

Table 47: Damage Matrix for Small Oil Refineries with Anchored Components

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	84	14	0	1	0	100
80	76	21	0	2	0	100
178	55	35	2	6	2	100
476	32	42	7	12	7	100

976	19	39	12	17	14	100
2475	8	28	16	20	28	100

Table 48: Damage Matrix for Medium/Large Oil Refineries with Anchored Components

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	97	3	0	0	0	100
80	93	7	1	0	0	100
178	78	19	3	0	0	100
476	51	34	12	2	0	100
976	31	39	23	6	1	100
2475	14	33	35	12	6	100




Figure 101: Fragility Functions for Small Oil Refineries with Anchored Components




Figure 102: Fragility Functions for Medium/Large Oil Refineries with Anchored Components

Pumping plants are classified into low seismic reinforced concrete (RC) buildings and high seismic RC buildings. The fragility curves (Figure 103) for anchored pumping plants are presented for damage states for slight, moderate, extensive and collapse limit states. Results are presented in terms of damage matrix (Figure 104) and show that anchored low seismic RC buildings exceeding 33% slight, 42% moderate, 9% extensive and 4% collapse limit states. The detailed damage matrix for different probability of exceedance is shown in Table 49.




Figure 103: Fragility function for High Seismic Pumping Plants with Anchored Components

Table 49: Damage Matrix for High Seismic Pumping Plants with Anchored Components

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	45	42	13	1	0	100
80	36	44	18	1	1	100
178	22	42	31	4	2	100
476	11	33	42	9	4	100
976	6	24	47	15	7	100
2475	3	15	45	24	14	100




Figure 104: Damage Matrix for High Seismic Pumping Plants with Anchored Components

Tank farms are classified with anchored and unanchored components. The fragility curves for anchored tank farms are shown in Figure 105 for damage states slight, moderate, extensive and collapse limit states. Results are presented in terms of damage matrix (Figure 106) and show that anchored low seismic RC buildings exceeding 38% slight, 0% moderate, 25% extensive and 5% collapse states. The detailed damage matrix for different probability of exceedance is shown in Table 50.




Figure 105: Fragility Functions for Anchored Tank Farms

Table 50: Damage Matrix for Anchored Tank Farms

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	84	13	0	2	0	100
80	76	20	0	4	0	100
178	55	32	0	12	1	100
476	32	38	0	25	5	100
976	19	35	0	35	11	100
2475	8	26	0	40	25	100




Figure 106: Damage Matrix for Anchored Tank Farms

The fragility functions (Figure 107) for communication facilities are plotted for four different limit states. These fragility curves are based on the probabilistic combination of subcomponent damage functions using boolean expressions. Results are presented in terms of damage matrix (Figure 108) and show that 29% slight, 38% moderate, 19% extensive and 3% collapse limit states exceeding at 10% probability of exceedance event. The detailed damage matrix for different probability of exceedance is shown in Table 51.




Figure 107: Fragility Functions for Communication Facilities with anchored components

Table 51: Damage Matrix for Communication Facilities with anchored components

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	45	42	12	2	0	100
80	36	43	17	3	0	100
178	22	39	29	9	1	100
476	11	29	38	19	3	100
976	6	19	39	28	7	100
2475	3	10	34	38	14	100




Figure 108: Damage Matrix for Communication Facilities with anchored components

Water treatment plants are classified into anchored and unanchored plants in this report. The fragility curves from SRM-LIFE (2007) are employed for the vulnerability assessment of water treatment plants. These were derived through fault-tree analysis, using the fault-tree and the fragility curves of sub-components proposed in HAZUS methodology (NIBS 2004). These employed curves are applicable to water treatment plants with anchored components and no backup power. Four different damage states such as slight, moderate, extensive and collapse are considered herein and their corresponding fragility curves are presented in the Figure 109. Results are presented in terms of damage matrix (Figure 110) and show that 19% slight, 55% moderate, 21% extensive and 6% collapse limit states exceeding at 10% probability of exceedance event for anchored water treatment plants. The detailed damage matrix for different probability of exceedance is shown in Table 52.




Figure 109: Fragility Functions for Anchored Water Treatment Plant

Table 52: Damage Matrix for Anchored Water Treatment Plant

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	37	61	1	1	0	100
80	18	77	0	4	0	100
178	3	64	22	10	1	100
476	0	19	55	21	6	100
976	0	3	56	28	12	100
2475	0	0	42	33	25	100




Figure 110: Damage Matrix for Anchored Water Treatment Plant

Waste-water treatment plants are classified into low seismic RC buildings and high seismic RC buildings. The fragility curves (Figures 111-112) for anchored waste-water treatment plants are presented for damage states slight, moderate, extensive and collapse. The fragility curves from SRM-LIFE (2007) are employed for the vulnerability assessment of waste-water treatment plants. Results are presented in terms of damage matrices (Figures 113-114) and show that anchored low seismic RC buildings exceeding 13% slight, 51% moderate, 7% extensive and 28% collapse limit states. Similarly, for anchored high seismic RC buildings 13% slight, 51% moderate, 33% extensive and 2% collapse limit states may exceed at 10% probability of exceedance event. The detailed damage matrices for different probability of exceedance are shown in Tables 53-54.




Figure 111: Fragility function for Low Seismic RC Building Waste Water Treatment Plant




Figure 112: Fragility function for High Seismic RC Building Waste Water Treatment Plant

Table 53: Damage Matrix for Low Seismic RC Building Waste Water Treatment Plant

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	39	59	0	1	1	100
80	22	73	2	2	1	100

178	5	65	15	4	11	100
476	0	13	51	7	28	100
976	0	1	45	8	46	100
2475	0	0	26	7	67	100

Table 54: Damage Matrix for High Seismic RC Building Waste Water Treatment Plant

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	39	59	0	2	0	100
80	22	73	2	3	0	100
178	5	65	15	15	0	100
476	0	13	51	33	2	100
976	0	1	45	47	7	100
2475	0	0	26	57	17	100




Figure 113: Damage Matrix for Low Seismic RC Building Waste Water Treatment Plant




Figure 114: Fragility function for High Seismic RC Building Waste Water Treatment Plant

Pumping Stations are classified into low seismic RC buildings and high seismic RC buildings. The fragility curves (Figures 115-116) for anchored pumping stations are presented for damage states slight, moderate, extensive and collapse. The fragility curves from SRM-LIFE (2007) are employed for the vulnerability assessment of pumping stations. Results are presented in terms of damage matrices (Figure 117-118) and show that anchored low seismic RC buildings exceeding 4% slight, 33% moderate, 16% extensive and 46% collapse limit states. Similarly, for anchored high seismic RC buildings 26% slight, 71% moderate, 2% extensive and 1% collapse limit states may exceed at 10% probability of exceedance event. The detailed damage matrices for different probability of exceedance are shown in Tables 55-56.




Figure 115: Fragility Functions for Low Seismic RC Building Pumping Stations




Figure 116: Fragility Functions for High Seismic RC Building Pumping Stations

Table 55: Damage Matrix for Low Seismic RC Building Pumping Stations

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	18	25	37	8	12	100
80	11	20	42	10	17	100
178	4	11	42	14	30	100
476	1	4	33	16	46	100
976	0	2	24	15	59	100

2475	0	0	14	13	72	100
-------------	---	---	----	----	----	-----

Table 56: Damage Matrix for High Seismic RC Building Pumping Stations

Return Period	None	Slight	Moderate	Extensive	Collapse	Total
Years	%	%	%	%	%	%
53	37	59	5	0	0	100
80	18	70	11	0	0	100
178	3	59	38	0	0	100
476	0	26	71	2	1	100
976	0	10	84	5	2	100
2475	0	2	83	11	4	100




Figure 117: Damage Matrix for Low Seismic RC Building Pumping Stations




Figure 118: Damage Matrix for High Seismic RC Building Pumping Stations

Chapter 8 – Conclusions

This report presents results of direct physical damage assessment of built infrastructure in Karachi including buildings, bridges, electric power network system, harbour system, oil and gas system, telecommunication system, and water and waste water systems.

The work limited to the development of damage matrices considering probabilistic earthquakes to existing structures given knowledge of typologies, classification, and the ground motion intensity measure (i.e., peak ground acceleration-PGA). Damage states describing the level of damage to each of the existing structure classification are defined as minor, moderate, extensive and collapse. Fragility curves are developed for each classification based on empirical and analytical approaches. The work was mainly divided into four steps. In the first step, a detailed data collection rubric considering the scope of the project for considered inventory has been developed. In the second step, GIS mapping has been done based on typology classification regarding variant existing structures. In the third step, intensity measure peak ground acceleration (PGA) has been extracted from the hazard analysis for different probability of exceedance having a specific return period. In the fourth and final step, the suitable fragility curves are identified from the literature and the corresponding damage matrices for different structures have been plotted.

Results show that 25% reinforced concrete buildings, 26% unreinforced concrete buildings, 44% bridges, 10% electric power network system, 5% oil and gas system, 3% telecommunication systems and 9% water and waste water systems are susceptible to collapse at 10% probability of exceedance earthquake in 50 years.

References

- SYNER-G (2011).** *Systemic Seismic Vulnerability and Risk Analysis for Buildgins, Lifeline Networks and Infrastructures Safety Gain*. European Collaborative research Project. <http://www.vce.at/SYNER-G/> 2011.
- National Institute of Building Sciences (NIBS) 2004.** *HAZUS-MH: Users's Manual and Technical Manuals*. Report prepared for the Federal Emergency Management Agency, Washington, D.C.
- Argyroudis, S., Pitilakis, K., (2012).** *Seismic fragility curves of shallow tunnels in alluvial deposits*. Soil Dynamics and Earthquake Engineering, 35, pp.1-12.
- Qiu, W., Huang, G., Zhou, H., Xu, W., (2018).** *Seismic Vulnerability Analysis of Rock Mountain Tunnel*. Int. J. Geomech., 18(3).
- Rossetto, T. and Elnashai, A. (2003).** *Derivation of Vulnerability Functions for European-Type RC Structures Based on Observational Data*. Engineering Structures, Vol. 25, No. 10, pp. 1241-1263
- Rossetto T., Elnashai A. (2005).** *A new analytical procedure for the derivation of displacement-based vulnerability curves for populations of RC structures*. Engineering Structures 27(3): 397-409.
- Rota M., Penna A., Strobbia C. (2006).** *Typological fragility curves from Italian earthquake damage data*. 1st European Conference on Earthquake Engineering and Seismology, Geneva, Switzerland.
- Rota M., Penna A. and Strobbia C.L. (2008).** *Processing Italian damage data to derive typological fragility curves*. Soil Dynamics and Earthquake Engineering 28:10-11, 933-947.
- Rota M., Penna A., Magenes G. (2010).** *A methodology for deriving analytical fragility curves for masonry buildings based on stochastic nonlinear analyses*. Engineering Structures 32: 1312-1323.
- Spence, R., So, E., Jenny, S., Castella, H., Ewald, M., & Booth, E. (2008).** *The Global Earthquake Vulnerability Estimation System (GEVES): an approach for earthquake risk assessment for insurance applications*. Bulletin of Earthquake Engineering, 6(3), 463-483.
- Building Code Of Pakistan Seismic Provisions (BCP)-2007.**
- Khan R A, Kumar M, Ahmed M, Rafi M M, and Lodi S H. (2015).** *Earthquake Damage assessment of Bridges in Karachi*. NED University Journal Of Research - Structural Mechanics, Vol Xii, No. 3.
- FEMA (2004).** **Fema 450:** *The 2003 Nehrps Recommended Provisions for New Building and Other Structures*. Washington D.C., Federal Emergency Management Agency (FEMA).
- Leelardcharoen, K. (2005).** *Interdependent Performance of Power and Water Networks*. Student Leadership Council Online Magazine. Urbana, IL, Mid-America Earthquake Center. 5: 1-23.
- Lemaréchal, C., A. Ouorou, and G. Petrou (2010).** *"Robust Network Design in Telecommunications under Polytope Demand Uncertainty."* European Journal of Operational Research 206(3): 634-641.
- Leelardcharoen, K., L. Dueñas-Osorio, J. I. Craig, and B. J. Goodno (2011).** *Seismic Fragility Analysis of Telecommunication Systems*. 11th International Conference of Applications of Statistics and Probabilistic in Civil Engineering, ETH Zurich, Switzerland, CRC Press.
- Adachi, T. (2007).** *Impact of Cascading Failures on Performance Assessment of Civil Infrastructure Systems*. PhD, Georgia Institute of Technology.
- Melchers, R. E. (1999).** *Structural reliability analysis and prediction*. 2d ed. West Sussex, England: John Wiley & Sons.

Lodi S H, Kumar M and Virk M S. (2015). *Predictive Relationship for Estimation of Vs30 Using Shallow Bore Logs for Karachi.* Geotech Geol Eng. 33:559–573 DOI 10.1007/s10706-014-9840-x

Kumar M, Arfeen R and Lodi S H. (2015). *Seismic Loss Estimation Of Low-Rise Reinforced Concrete Structures In Karachi.* NED University Journal Of Research – Structural Mechanics, Vol Xii, No. 3.

Kumar M, Khalid F, Afreen R and Lodi S H. (2017). *Fragility Functions Of Low-Rise Reinforced Concrete Structures With And Without Infill Walls.* NED University Journal Of Research - Structural Mechanics, Vol Xiv, No. 3.

Rafi M., Lodi S H, Alam N., Ahmed M., & Silveira, D. (2012). *Assessment of Seismic Performance of Adobe Structures in Pakistan and Portugal.* Lisbon: World Conference on Earthquake Engineering.

Alexoudi M., Pitilakis K. 2003. *Vulnerability assessment of lifelines and essential facilities (WP06): methodological handbook – Appendix 7: gas utility system.* Risk-UE Report n° GTR-RSK 0101-152av7

SRMLIFE, (2003-2007). *Development of a global methodology for the vulnerability assessment and risk management of lifelines, infrastructures and critical facilities.* Application to the metropolitan area of Thessaloniki. Research Project, General Secretariat for Research and Technology, Greece.

SYNER-G, (2009-2011). *Systemic Seismic Vulnerability and Risk Analysis for Buildings, Lifeline Networks and Infrastructures Safety Gain.* Research Project, European Commission, 7th Framework Programme.

Pitilakis K., Alexoudi M., Kakderi K., Manou D., Batur E., Raptakis D. (2005). *Vulnerability analysis of water systems in strong earthquakes.* The case of Lefkas (Greece) and Düzce (Turkey). International Symposium on the Geodynamics of Eastern Mediterranean: Active Tectonics of the Aegean, Istanbul, Turkey.

Pitilakis K., Alexoudi A., Argyroudis S., Monge O., Martin C. (2006). *Vulnerability and risk assessment of lifelines.* In Assessing and Managing Earthquake Risk, Geo-scientific and Engineering Knowledge for Earthquake Risk Mitigation: developments, tools, techniques, Eds. X. Goula, C. S. Oliveira, A. Roca, Springer, ISBN 1-4020-3524-1. pp. 185-211.

Dueñas-Osorio, L., Craig, J.I. and Goodno, B.J. (2007). *Seismic Response of Critical Interdependent Networks.* Earthquake Engineering and Structural Dynamics, Special Issue on Earthquake Engineering for Electric Power Equipment and Lifeline Systems, Vol. 36, No. 2, pp. 285-306.

FEMA 2003. *HAZUS-MH MRI: Technical Manual, Vol. Earthquake Model.* Federal Emergency Management Agency, Washington DC